

**MTC – Springdale Hall Restroom**  
**– Airport Campus**

**1260 Lexington Drive**  
**Columbia, South Carolina 29170**  
PROJECT NO. H59-N241-CL



**POND**

1301 Gervais Street, Suite 1300  
Columbia, South Carolina 29201  
803.799.6502  
[www.pondco.com](http://www.pondco.com)



06/07/23

**June 7, 2023**  
**Pond Project No. 1230236**  
**Construction Documents**

**TABLE OF CONTENTS – TASK ORDER**

**PROJECT NAME:** MTC - Springdale Hall Restroom - Airport Campus

**PROJECT NUMBER:** H59-N241-CL

<b><u>SECTION</u></b>	<b><u>NUMBER OF PAGES</u></b>
<b>Table of Contents.....</b>	<b>1</b>
<b>SE-688, Task Order Quote Form.....</b>	<b>1</b>
<b>SE-355, Performance Bond.....</b>	<b>2</b>
<b>SE-357, Labor &amp; Material Payment Bond.....</b>	<b>2</b>
<b>SE-690, Construction Services Task Order.....</b>	<b>1</b>
<b>SE-695, Construction Services Task Order Modification.....</b>	<b>1</b>

**TECHNICAL SPECIFICATIONS**

- Section 010000 - MTC General Requirements
- Section 080641 - Door Hardware Schedule
- Section 081213 - Hollow Metal Frames
- Section 081416 - Flush Wood Doors
- Section 092216 - Non-Structural Metal Framing
- Section 092900 - Gypsum Board
- Section 093000 - Porcelain Tile
- Section 095123 - Acoustical Ceiling Tile
- Section 096513 - Resilient Base and Accessories
- Section 096519 - Resilient Tile Flooring
- Section 099123 - Interior Painting
- Section 102800 - Toilet and Bath Accessories

# SE-688

## TASK ORDER QUOTE FORM

---

QUOTE SUBMITTED BY: \_\_\_\_\_  
*(Task Order Contractor's Name)*

QUOTE SUBMITTED TO: Midlands Technical College  
*(Agency's Name)*

FOR: PROJECT NAME: MTC - Springdale Hall Restroom - Airport Campus  
 PROJECT NUMBER: H59-N241-CL

---

### OFFER

- § 1. In response to the solicitation for a Task Order Quote for the above Project, the undersigned **TASK ORDER CONTRACTOR** proposes and agrees, if this Quote is accepted, to enter into a Task Order with the Agency and to perform all Work as specified or indicated in the Solicitation Documents, for the prices and within the time frames indicated below.
- § 2. **TASK ORDER CONTRACTOR** agrees that the Date of Commencement of the Work shall be established in Construction Services Task Order to be issued by the Agency. Contractor agrees to substantially complete the Work within 90 Calendar Days from the Date of Commencement, subject to adjustments as provided in the Contract Documents.
- § 3 **TASK ORDER CONTRACTOR** further agrees that from the compensation to be paid, the Agency shall retain as Liquidated Damages the amount of \$ 150.00 for each Calendar Day the actual construction time required to achieve Substantial Completion exceeds the agreed upon date provided in the Contract Documents. This amount is intended by the parties as the predetermined measure of compensation for actual damages, not as a penalty for nonperformance.
- § 4 **TASK ORDER CONTRACTOR** herewith submits its offer to provide all labor, materials, equipment, tools of trades and labor, accessories, appliances, warranties and guarantees, and to pay all royalties, fee, permits, licenses, and applicable taxes necessary to complete the following items of construction work:

§ 4.1 **TASK ORDER WORK** *(as indicated in the Solicitation Documents and generally described as follows):* \_\_\_\_\_

§ 4.2 **TASK ORDER QUOTE** \$ \_\_\_\_\_  
*(enter QUOTE in numbers only – MUST be between \$90,000 & \$350,000)*

---

This Quote is hereby submitted on behalf of the Task Order Contractor named above.

SIGNATURE: \_\_\_\_\_  
*(Task Order Contractor's Representative)*

DATE: \_\_\_\_\_  
*(Print or Type Name of Task Order Contractor's Representative)*

# SE-355 PERFORMANCE BOND

**KNOW ALL MEN BY THESE PRESENTS**, that *(Insert full name or legal title and address of Contractor)*

Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
\_\_\_\_\_

hereinafter referred to as “Contractor”, and *(Insert full name and address of principal place of business of Surety)*

Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
\_\_\_\_\_

hereinafter called the “surety”, are jointly and severally held and firmly bound unto *(Insert full name and address of Agency)*

Name: Midlands Technical College  
Address: 1260 Lexington Dr.  
West Columbia, SC 29170

hereinafter referred to as “Agency”, or its successors or assigns, the sum of \_\_\_\_\_ (\$ \_\_\_\_\_), being the sum of the Bond to which payment to be well and truly made, the Contractor and Surety bind themselves, their heirs, executors, administrators, successors and assigns, jointly and severally, firmly by these presents.

**WHEREAS**, Contractor has by written agreement dated \_\_\_\_\_ entered into a contract with Agency to construct

State Project Name: MTC - Springdale Hall Restroom - Airport Campus

State Project Number: H59-N241-CL

Brief Description of Awarded Work: The project is to provide a single unisex bathroom in the building and add doors at front entry to create a vestibule.

in accordance with Drawings and Specifications prepared by *(Insert full name and address of A/E)*

Name: Pond  
Address: 1001 Gervais Street, Suite 1300  
Columbia, SC 29201

which agreement is by reference made a part hereof, and is hereinafter referred to as the Contract.

**IN WITNESS WHEREOF**, Surety and Contractor, intending to be legally bound hereby, subject to the terms stated herein, do each cause this Performance Bond to be duly executed on its behalf by its authorized officer, agent or representative.

**DATED this** \_\_\_\_\_ **day of** \_\_\_\_\_, **2** \_\_\_\_\_  
*(shall be no earlier than Date of Contract)*

**BOND NUMBER** \_\_\_\_\_

## CONTRACTOR

**By:** \_\_\_\_\_  
(Seal)

**Print Name:** \_\_\_\_\_

**Print Title:** \_\_\_\_\_

**Witness:** \_\_\_\_\_

## SURETY

**By:** \_\_\_\_\_  
(Seal)

**Print Name:** \_\_\_\_\_

**Print Title:** \_\_\_\_\_  
*(Attach Power of Attorney)*

**Witness:** \_\_\_\_\_

*(Additional Signatures, if any, appear on attached page)*

**SE-355****PERFORMANCE BOND****NOW, THEREFORE, THE CONDITION OF THIS OBLIGATION IS SUCH THAT:**

1. The Contractor and the Surety, jointly and severally, bind themselves, their heirs, executors, administrators, successors and assigns to the Agency for the full and faithful performance of the contract, which is incorporated herein by reference.
2. If the Contractor performs the contract, the Surety and the Contractor have no obligation under this Bond, except to participate in conferences as provided in paragraph 3.1.
3. The Surety's obligation under this Bond shall arise after:
  - 3.1 The Agency has notified the Contractor and the Surety at the address described in paragraph 10 below, that the Agency is considering declaring a Contractor Default and has requested and attempted to arrange a conference with the Contractor and the Surety to be held not later than 15 days after receipt of such notice to discuss methods of performing the Contract. If the Agency, the Contractor and the Surety agree, the Contractor shall be allowed a reasonable time to perform the Contract, but such an agreement shall not waive the Agency's right, if any, subsequently to declare a Contractor Default; or
  - 3.2 The Agency has declared a Contractor Default and formally terminated the Contractor's right to complete the Contract.
4. The Surety shall, within 15 days after receipt of notice of the Agency's declaration of a Contractor Default, and at the Surety's sole expense, take one of the following actions:
  - 4.1 Arrange for the Contractor, with consent of the Agency, to perform and complete the Contract; or
  - 4.2 Undertake to perform and complete the Contract itself, through its agents or through independent contractors; or
  - 4.3 Obtain bids or negotiated proposals from qualified contractors acceptable to the Agency for a contract for performance and completion of the Contract, arrange for a contract to be prepared for execution by the Agency and the contractor selected with the Agency's concurrence, to be secured with performance and payment bonds executed by a qualified surety equivalent to the Bonds issued on the Contract, and pay to the Agency the amount of damages as described in paragraph 7 in excess of the Balance of the Contract Sum incurred by the Agency resulting from the Contractor Default; or
  - 4.4 Waive its right to perform and complete, arrange for completion, or obtain a new contractor, and:
    - 4.4.1 After investigation, determine the amount for which it may be liable to the Agency and, within 60 days of waiving its rights under this paragraph, tender payment thereof to the Agency; or
    - 4.4.2 Deny liability in whole or in part and notify the Agency, citing the reasons therefore.
5. Provided Surety has proceeded under paragraphs 4.1, 4.2, or 4.3, the Agency shall pay the Balance of the Contract Sum to either:
  - 5.1 Surety in accordance with the terms of the Contract; or
  - 5.2 Another contractor selected pursuant to paragraph 4.3 to perform the Contract.
  - 5.3 The balance of the Contract Sum due either the Surety or another contractor shall be reduced by the amount of damages as described in paragraph 7.
6. If the Surety does not proceed as provided in paragraph 4 with reasonable promptness, the Surety shall be deemed to be in default on this Bond 15 days after receipt of written notice from the Agency to the Surety demanding that the Surety perform its obligations under this Bond, and the Agency shall be entitled to enforce any remedy available to the Agency.
  - 6.1 If the Surety proceeds as provided in paragraph 4.4 and the Agency refuses the payment tendered or the Surety has denied liability, in whole or in part, then without further notice the Agency shall be entitled to enforce any remedy available to the Agency.
  - 6.2 Any dispute, suit, action or proceeding arising out of or relating to this Bond shall be governed by the Dispute Resolution process defined in the Contract Documents and the laws of the State of South Carolina.
7. After the Agency has terminated the Contractor's right to complete the Contract, and if the Surety elects to act under paragraph 4.1, 4.2, or 4.3 above, then the responsibilities of the Surety to the Agency shall be those of the Contractor under the Contract, and the responsibilities of the Agency to the Surety shall be those of the Agency under the Contract. To a limit of the amount of this Bond, but subject to commitment by the Agency of the Balance of the Contract Sum to mitigation of costs and damages on the Contract, the Surety is obligated to the Agency without duplication for:
  - 7.1 The responsibilities of the Contractor for correction of defective Work and completion of the Contract; and
  - 7.2 Additional legal, design professional and delay costs resulting from the Contractor's Default, and resulting from the actions or failure to act of the Surety under paragraph 4; and
  - 7.3 Damages awarded pursuant to the Dispute Resolution Provisions of the Contract. Surety may join in any Dispute Resolution proceeding brought under the Contract and shall be bound by the results thereof; and
  - 7.4 Liquidated Damages, or if no Liquidated Damages are specified in the Contract, actual damages caused by delayed performance or non-performance of the Contractor.
8. The Surety shall not be liable to the Agency or others for obligations of the Contractor that are unrelated to the Contract, and the Balance of the Contract Sum shall not be reduced or set-off on account of any such unrelated obligations. No right of action shall accrue on this Bond to any person or entity other than the Agency or its heirs, executors, administrators, or successors.
9. The Surety hereby waives notice of any change, including changes of time, to the contract or to related subcontracts, purchase orders and other obligations.
10. Notice to the Surety, the Agency or the Contractor shall be mailed or delivered to the address shown on the signature page.
11. Definitions
  - 11.1 Balance of the Contract Sum: The total amount payable by the Agency to the Contractor under the Contract after all proper adjustments have been made, including allowance to the Contractor of any amounts to be received by the Agency in settlement of insurance or other Claims for damages to which the Contractor is entitled, reduced by all valid and proper payments made to or on behalf of the Contractor under the Contract.
  - 11.2 Contractor Default: Failure of the Contractor, which has neither been remedied nor waived, to perform the Contract or otherwise to comply with the terms of the Contract.

# SE-357 LABOR & MATERIAL PAYMENT BOND

KNOW ALL MEN BY THESE PRESENTS, that *(Insert full name or legal title and address of Contractor)*

Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
\_\_\_\_\_

hereinafter referred to as "Contractor", and *(Insert full name and address of principal place of business of Surety)*

Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
\_\_\_\_\_

hereinafter called the "surety", are jointly and severally held and firmly bound unto *(Insert full name and address of Agency)*

Name: Midlands Technical College  
Address: 1260 Lexington Dr.  
West Columbia, SC 29170

hereinafter referred to as "Agency", or its successors or assigns, the sum of \_\_\_\_\_ (\$ \_\_\_\_\_), being the sum of the Bond to which payment to be well and truly made, the Contractor and Surety bind themselves, their heirs, executors, administrators, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, Contractor has by written agreement dated \_\_\_\_\_ entered into a contract with Agency to construct

State Project Name: MTC - Springdale Hall Restroom - Airport Campus  
State Project Number: H59-N241-CL  
Brief Description of Awarded Work: The project is to provide a single unisex bathroom in the building and add doors at front entry to create a vestibule.

in accordance with Drawings and Specifications prepared by *(Insert full name and address of A/E)*

Name: Pond  
Address: 1001 Gervais Street, Suite 1300  
Columbia, SC 29201

which agreement is by reference made a part hereof, and is hereinafter referred to as the Contract.

IN WITNESS WHEREOF, Surety and Contractor, intending to be legally bound hereby, subject to the terms stated herein, do each cause this Labor & Material Payment Bond to be duly executed on its behalf by its authorized officer, agent or representative.

DATED this \_\_\_\_\_ day of \_\_\_\_\_, 2\_\_\_\_\_  
*(shall be no earlier than Date of Contract)*

BOND NUMBER \_\_\_\_\_

**CONTRACTOR**

**SURETY**

By: \_\_\_\_\_  
(Seal)

By: \_\_\_\_\_  
(Seal)

Print Name: \_\_\_\_\_

Print Name: \_\_\_\_\_

Print Title: \_\_\_\_\_

Print Title: \_\_\_\_\_  
*(Attach Power of Attorney)*

Witness: \_\_\_\_\_

Witness: \_\_\_\_\_

*(Additional Signatures, if any, appear on attached page)*

**SE-357****LABOR & MATERIAL PAYMENT BOND****NOW, THEREFORE, THE CONDITION OF THIS OBLIGATION IS SUCH THAT:**

1. The Contractor and the Surety, jointly and severally, bind themselves, their heirs, executors, administrators, successors and assigns to the Agency to pay for all labor, materials and equipment required for use in the performance of the Contract, which is incorporated herein by reference.
  2. With respect to the Agency, this obligation shall be null and void if the Contractor:
    - 2.1 Promptly makes payment, directly or indirectly, for all sums due Claimants; and
    - 2.2 Defends, indemnifies and holds harmless the Agency from all claims, demands, liens or suits by any person or entity who furnished labor, materials or equipment for use in the performance of the Contract.
  3. With respect to Claimants, this obligation shall be null and void if the Contractor promptly makes payment, directly or indirectly, for all sums due.
  4. With respect to Claimants, and subject to the provisions of Title 29, Chapter 5 and the provisions of §11-35-3030(2)(c) of the SC Code of Laws, as amended, the Surety's obligation under this Bond shall arise as follows:
    - 4.1 Every person who has furnished labor, material or rental equipment to the Contractor or its subcontractors for the work specified in the Contract, and who has not been paid in full therefore before the expiration of a period of ninety (90) days after the date on which the last of the labor was done or performed by him or material or rental equipment was furnished or supplied by him for which such claim is made, shall have the right to sue on the payment bond for the amount, or the balance thereof, unpaid at the time of institution of such suit and to prosecute such action for the sum or sums justly due him.
    - 4.2 A remote claimant shall have a right of action on the payment bond upon giving written notice by certified or registered mail to the Contractor within ninety (90) days from the date on which such person did or performed the last of the labor or furnished or supplied the last of the material or rental equipment upon which such claim is made.
    - 4.3 Every suit instituted upon a payment bond shall be brought in a court of competent jurisdiction for the county or circuit in which the construction contract was to be performed, but no such suit shall be commenced after the expiration of one year after the day on which the last of the labor was performed or material or rental equipment was supplied by the person bringing suit.
  5. When the Claimant has satisfied the conditions of paragraph 4, the Surety shall promptly and at the Surety's expense take the following actions:
    - 5.1 Send an answer to the Claimant, with a copy to the Agency, within sixty (60) days after receipt of the claim, stating the amounts that are undisputed and the basis for challenging any amounts that are disputed.
    - 5.2 Pay or arrange for payment of any undisputed amounts.
    - 5.3 The Surety's failure to discharge its obligations under this paragraph 5 shall not be deemed to constitute a waiver of defenses the Surety or Contractor may have or acquire as to a claim. However, if the Surety fails to discharge its obligations under this paragraph 5, the Surety shall indemnify the Claimant for the reasonable attorney's fees the Claimant incurs to recover any sums found to be due and owing to the Claimant.
  6. Amounts owed by the Agency to the Contractor under the Contract shall be used for the performance of the Contract and to satisfy claims, if any, under any Performance Bond. By the Contractor furnishing and the Agency accepting this Bond, they agree that all funds earned by the contractor in the performance of the Contract are dedicated to satisfy obligations of the Contractor and the Surety under this Bond, subject to the Agency's prior right to use the funds for the completion of the Work.
  7. The Surety shall not be liable to the Agency, Claimants or others for obligations of the Contractor that are unrelated to the Contract. The Agency shall not be liable for payment of any costs or expenses of any claimant under this bond, and shall have under this Bond no obligations to make payments to, give notices on behalf of, or otherwise have obligations to Claimants under this Bond.
  8. The Surety hereby waives notice of any change, including changes of time, to the Contract or to related Subcontracts, purchase orders and other obligations.
  9. Notice to the Surety, the Agency or the Contractor shall be mailed or delivered to the addresses shown on the signature page. Actual receipt of notice by Surety, the Agency or the contractor, however accomplished, shall be sufficient compliance as of the date received at the address shown on the signature page.
  10. By the Contractor furnishing and the Agency accepting this Bond, they agree that this Bond has been furnished to comply with the statutory requirements of the South Carolina Code of Laws, as amended, and further, that any provision in this Bond conflicting with said statutory requirements shall be deemed deleted herefrom and provisions conforming to such statutory or other legal requirement shall be deemed incorporated herein. The intent is that this Bond shall be construed as a statutory Bond and not as a common law bond.
  11. Upon request of any person or entity appearing to be a potential beneficiary of this bond, the Contractor shall promptly furnish a copy of this Bond or shall permit a copy to be made.
  12. Any dispute, suit, action or proceeding arising out of or relating to this Bond shall be governed by the laws of the State of South Carolina.
- 13. DEFINITIONS**
- 13.1 Claimant: An individual or entity having a direct contract with the Contractor or with a Subcontractor of the Contractor to furnish labor, materials, or equipment for use in the performance of the Contract. The intent of this Bond shall be to include without limitation in the terms "labor, materials or equipment" that part of water, gas, power, light, heat, oil, gasoline, telephone service or rental equipment used in the Contract, architectural and engineering services required for performance of the Work of the Contractor and the Contractor's Subcontractors, and all other items for which a mechanic's lien might otherwise be asserted.
  - 13.2 Remote Claimant: A person having a direct contractual relationship with a subcontractor of the Contractor or subcontractor, but no contractual relationship expressed or implied with the Contractor.
  - 13.3 Contract: The agreement between the Agency and the Contractor identified on the signature page, including all Contract Documents and changes thereto.

**SE-690**

**CONSTRUCTION SERVICES TASK ORDER**

AGENCY: Midlands Technical College

TASK ORDER PROJECT NAME: MTC - Springdale Hall Restroom - Airport Campus

TASK ORDER PROJECT NUMBER: H59-N241-CL

TOC CONTRACT NUMBER: H59-C002-CB

CONTRACTOR: \_\_\_\_\_

**COST INFORMATION:**

	<u>TASK ORDER</u>	<u>TOC CONTRACT</u>
1. Maximum Total Potential Amount of this TOC:		\$ 4,000,000.00
2. Maximum Total Amount Allowed for Task Order:	\$ 350,000.00	
3. Amount of this Task Order:	\$	
4. Total Amount of Previous Task Orders (including Modifications):		\$
5. Total Amount of TOC, Including this Task Order:		\$ 0.00
6. Balance Remaining for this TOC:		\$ 0.00

**SCHEDULE:**

1. Date of Commencement:	
2. Days Allowed to Complete the Task Order, including Alternates:	
3. Date of Substantial Completion:	

**DESCRIPTION OF TASK ORDER SCOPE OF WORK:** *(attach Contractor's Proposal)* The project is to provide a single unisex bathroom in the building and add doors at front entry to create a vestibule.

**LIST OF TASK ORDER DOCUMENTS:** *(refer to attachments as necessary)* Drawings and specifications dated June 7, 2023 prepared by Pond

The Agency and the Contractor hereby agree, as indicated by the signatures below, to the scope of work identified in the Contract Documents listed above, the Contractor's Quote dated the \_\_\_\_ day of \_\_\_\_, 20 \_\_\_\_, and this Task Order which shall be assigned to the Task Order Contract identified above.

**NOTICE TO PROCEED** is hereby given on this the \_\_\_\_ day of \_\_\_\_, 20 \_\_\_\_\_. The Dates of Commencement and Substantial Completion are as noted above and shall be used for determining completion and the applicability of Liquidated Damages. Liquidated Damages in the amount of \$ 150.00 per day will be assessed for failure to complete the Work by the agreed upon date of completion. Failure to commence actual work on this Task Order within seven (7) days from the Date of Commencement will entitle the Agency to consider the Contractor non-responsible, and may withdraw this Task Order and terminate the Contract in accordance with the Contract Documents.

TASK ORDER is within Agency Construction Contract Certification of: \$ 100,000.00 Yes  No

IF "NO", ATTACH OSE APPROVAL EMAIL TO THIS SE-690 AND PLACE IN PROCUREMENT FILE.

**AGENCY:**

BY: \_\_\_\_\_  
*(Signature of Representative)*

Print Name: \_\_\_\_\_

Print Title: \_\_\_\_\_

Date: \_\_\_\_\_

**CONTRACTOR**

BY: \_\_\_\_\_  
*(Signature of Representative)*

Print Name: \_\_\_\_\_

Print Title: \_\_\_\_\_

Date: \_\_\_\_\_

**COMPLETION CONFIRMATION BY AGENCY:**

ACTUAL COMPLETION DATE: \_\_\_\_\_

LIQUIDATED DAMAGES ASSESSED: \_\_\_\_\_

CONFIRMED BY: \_\_\_\_\_  
*(Signature of Agency Representative)*

DATE: \_\_\_\_\_

TITLE: \_\_\_\_\_



**SE-695**

MODIFICATION NO.: \_\_\_\_\_

**CONSTRUCTION SERVICES TASK ORDER MODIFICATION**

**AGENCY:** Midlands Technical College

**TASK ORDER PROJECT NAME:** MTC - Springdale Hall Restroom - Airport Campus

**TASK ORDER PROJECT NUMBER:** H59-N241-CL

**TOC CONTRACT NUMBER:** H59-C002-CB

**CONTRACTOR:** \_\_\_\_\_

	<u>TASK ORDER</u>	<u>TOC CONTRACT</u>
<b><u>COST INFORMATION:</u></b>		
1. Maximum Total Potential Amount of this TOC:		\$ 4,000,000.00
2. Maximum Total Amount Allowed for Task Order:	\$ 350,000.00	
3. Current Amount of this Task Order:		
4. Amount of this Modification:		
5. Adjusted Amount of this Task Order	\$ 0.00	
6. TOC Total Prior to this Modification (Sum of all Task Orders, including this one):		
7. TOC Total Including this Modification (Sum of all Task Orders):		\$ 0.00
8. Balance Remaining for this TOC:		\$ 4,000,000.00

**SCHEDULE:**

1. Date of Commencement:	
2. Previous Days Allowed To Complete the Task Order:	
3. Additional Days Added with this Modification:	
4. Revised Date of Substantial Completion:	

**DESCRIPTION OF TASK ORDER SCOPE MODIFICATION:** *(attach Contractor's Proposal)* \_\_\_\_\_

**LIST OF TASK ORDER MODIFICATION DOCUMENTS:** *(refer to attachments as necessary)* \_\_\_\_\_

The Agency and the Contractor hereby agree, as indicated by the signatures below, to the revised scope of work identified in the Modification Documents listed above, the Contractor's Quote dated the \_\_\_\_ day of \_\_\_\_, 20 \_\_\_\_, and this Task Order Modification, which shall be assigned to the Task Order Contract identified above.

**TASK ORDER, including MODIFICATION, is within Agency Construction Contract Certification of:** \$ \_\_\_\_\_ Yes  No

IF "NO", ATTACH OSE APPROVAL EMAIL TO THIS SE-695 AND PLACE IN PROCUREMENT FILE.

**AGENCY:**

**BY:** \_\_\_\_\_  
*(Signature of Representative)*

**PRINT NAME:** \_\_\_\_\_

**PRINT TITLE:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

**CONTRACTOR**

**BY:** \_\_\_\_\_  
*(Signature of Representative)*

**PRINT NAME:** \_\_\_\_\_

**PRINT TITLE:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

## SECTION 01 00 00 - MTC GENERAL REQUIREMENTS

### 1. GENERAL

- 1.1. This document defines the general requirements that govern all work at Midlands Technical College (MTC). It is a part of the Contract and shall have full force and effect and shall be as a part thereof.
- 1.2. Scope of Work of this construction project includes: The project is to provide a single unisex bathroom in the building and add doors at front entry to create a vestibule.
- 1.3. Contractor will provide construction work as described in this paragraph above, and the referenced drawings and specifications, as directed by Owner/Operations Department.

### 2. PERSONNEL

- 2.1. The Contractor is fully responsible for the performance and conduct of his employees at all times while on MTC campuses. The Contractor shall be responsible for selecting personnel who are well qualified to perform the required services, for supervising techniques used in their work and for keeping them informed of all improvements, changes, methods of operations.
- 2.2. The Contractor shall not allow any employee to perform work under this contract while under the influence of alcohol, drugs, or any other incapacitating agent. Use of any possession of alcoholic beverage and / or illegal drugs is prohibited on all State property. Violators will be dealt with according to law.
- 2.3. All personnel employed by the Contractor or any representative of the Contractor entering the site(s) shall comply with all security regulations which may be in effect during the contract period and shall be subject to such checks as may be deemed necessary. The Owner has authority to bar an individual from entry onto the site. Such action by the Owner shall not excuse the Contractor from fulfilling all requirements under this contract and shall not be the cause of any claim for additional compensation by the Contractor or claim by the individual.
- 2.4. No weapons of any type (guns, rifles, etc.) are brought on site or any MTC College property.

### 3. UTILITIES

- 3.1. When available, the Owner will provide utilities for use by the Contractor. The Contractor will provide for all connections, extensions, adaptations, and safety precautions needed in these connections. Utilities in this paragraph are limited to: (1) electrical, (2) water, (3) sanitary, and (4) storm sewer (if applicable). Contractor shall use all appropriate conservation measures. Temporary power, when needed, shall be the Contractor's responsibility.

### 4. SCHEDULES

- 4.1. If the scope of work or specifications require a schedule, a bar type progress chart will be submitted within 5 working days, identifying the proposed construction schedule. Thereafter a revised chart should be

submitted as least every two weeks identifying the original schedule, amended schedule (if any) as well as completed work.

## **5. OWNER'S USE OF PREMISES**

- 5.1. The Owner may continue to use the areas adjacent to the Work site for their intended purpose. The walk paths, sidewalks, and parking areas in the area of the project must be kept clear of materials, dirt, debris, etc., to allow for College traffic. If this is not possible, an approved alternate route of travel must be provided by the Contractor.
- 5.2. Occupancy of buildings: The building(s) will remain occupied during the work. The Contractor is responsible for taking necessary precautions to protect building, contents and personnel from damage to injury from their operations and from water entry into building during operations.
- 5.3. Any requests received by the Contractor from occupants to change the sequence or work must be referred to the Owners project manager for determination. No changes will be made unless agree to in writing by both the contractor and Owner prior to the execution of any agreed upon changes to work sequence.

## **6. CONTRACTOR'S USE OF PREMISES**

- 6.1. No job sign is required. If indicated on the Campus Map, furnish and install material delivery signs as shown. Signs shall be of approved size and color with lettering of approved style and contrasting color so as to be easily visible and readable.
- 6.2. An on-site Construction Office is not required for this work.
- 6.3. Contractor's personnel shall use Contractor provided facilities (toilet, water, vending and break) for all workers.
- 6.4. See Campus Map for site access and Contractor parking. Trucks may not drive on campus sidewalks. Except for permitted deliveries to the facility, and vehicles used in pursuit of the work (as opposed to transport of personnel or materials), vehicles of Contractor and Contractor's personnel shall park only in the area designated.
- 6.5. Lay-Down Areas: Prior to beginning operations, Contractor shall obtain approval of Owner for areas to be used as material storage, hoisting, holding, dumping, porta-pots, etc. Work will be restricted to approved locations.
- 6.6. Dumpsters located on the College Campuses are not for the disposal of construction debris. The Contractor shall be responsible for the disposal construction materials unless specified otherwise in the scope of work.
- 6.7. Contractor may work on the premises at any time. The Owner will be notified in writing if work is planned after normal working hours, on weekends or on holidays. Normal work hours are 7:00 AM until 5:00 PM. Work bid on a lump sum price will include a scheduled completion date and the contractor will be responsible for completing the work by the scheduled date at the bid price unless the Owner causes a delay which must be agreed in writing when a change or delay is made to the contractor.

- 6.8. Excessively noisy operations shall not be conducted between 8:00 am and 10:00 pm, and otherwise as required by the Owner from time to time. Work at times other than Owner's normal work hours shall be coordinated in advance so the Owner may notify appropriate parties.
- 6.9. The Contractor shall schedule utility interruptions with Owner at least 48 hours in advance. Scheduled interruptions shall be at the Owner's convenience. Do not interrupt any utility service without prior approval for each specific instance. Reschedule any interruption which must be handled other than as originally coordinated.
- 6.10. Before starting excavation, establish location and extent of underground utilities occurring in the area where digging will occur by careful hand excavation.
- 6.11. Immediately report damage to any existing utility encountered. Repair all damage to any active utility. Repair shall be handled as an emergency unless approved by the Owner for handling otherwise. The Contractor shall be responsible for all damage to all underground utilities.

## **7. DIFFERING SITE CONDITIONS:**

- 7.1. The Contractor must promptly and before the conditions are disturbed, notify the Owner in writing of any of the following:
- 7.2. Subsurface or latent physical conditions at the site differing materially from those indicated in this Contract document and the contract specifications and drawings.
- 7.3. Previously unknown physical conditions at the site of an unusual nature differing materially from those which may be ordinarily encountered and generally recognized as inherent in work of the character required in this Contract. The Contractor shall take proper measures to prevent damages to underground utilities located in the area of this project. The Contractor shall contact the Owner prior to penetrating the ground for a utility location check.
- 7.4. The Owner will promptly investigate the conditions. If the conditions are found to differ materially from those indicated or anticipated and will cause a change in the date of completion of the work quantity of materials called for in the work of this contract, the Contractor will be entitled to an equitable adjustment.
- 7.5. No claims for adjustment under the previous clause will be considered after completion of the work or following application for payment.
- 7.6. Parking Limitations: Contractor is to confine his operations at the site(s) to only those designed parking areas. There may not be adequate parking for Contractor and his personnel at each site(s).
  - 7.6.1. The Contractor shall not park on the grass or block entrances/exits to buildings. The Contractor will be held responsible for damage to shrubs, lawn and landscape damaged by their personnel. Temporary parking permits are required and will be provided by Operations or Campus Police.

## **8. EXIT DOOR ACCESS AND EMERGENCY EGRESS**

- 8.1. The Contractor shall keep fire exits free of obstructions at all time. When work occurs within the exit access corridors or within the exit itself, alternate routes for emergency exiting shall be identified by the Owner and appropriate temporary signage posted by the Contractor for the duration of exit access interruption.

## **9. INSURANCE**

- 9.1. Contractor shall add the following wording to their Liability Insurance as required by the State of South Carolina and Midlands Technical College. "Midlands Technical College, including its current and former trustees, officers, directors, employees, volunteer workers, agents, assigns and students."

## **10. MATERIALS**

- 10.1. Unless specified otherwise, all materials incorporated into the work shall be new and of first quality.
- 10.2. The Contractor shall closely coordinate all deliveries. Owner will not be responsible for any material delivered to Owner or for any charges arising from Owner's acceptance or refusal of deliveries.
- 10.3. The Contractor shall coordinate deliveries of significantly large, dangerous or otherwise unusual materials with Owner beforehand.
- 10.4. The Contractor shall store materials in a manner that will properly protect them from all contamination and hazards until used or removed from site. Labeled materials shall be kept in original containers until used.
- 10.5. The Contractor shall handle materials in such a manner as to deliver them to the point of use free of all damage, contamination, corrosion, etc.
- 10.6. In handling, storing, and/or disposing of any materials or chemicals considered hazardous or dangerous by South Carolina Department of Health and Environmental Control (SCDHEC), Environmental Protection Agency (EPA), Occupational Safety and Health Administration (OSHA), or National Fire Protection Agency (NFPA) and where these governing bodies require special handling, storage, or disposal of the material or chemical, abide by the procedures set forth by the governing body. If the material or chemical is encountered by demolition, excavation, or accident, and the Bidding Documents did not indicate its presence, or probable presence, immediately notify the Owner and proceed as directed. In such an event compensation will be handled by Change order.
- 10.7. The Contractor shall not order/purchase materials, equipment or products that are required to be submitted for Owner/Architect review. Submittals will be specified by the Owner/Architect and must be approved in writing before the Contractor procures the items identified in the submittal listing. It is the Contractor's responsibility to ensure the timeliness of the submittal process allowing adequate time for the Owner to review and approve the submittal documents.

## 11. SAFETY

- 11.1. Vehicles are to be locked when parked and unattended. Do not leave vehicles or equipment unattended with motor running or ignition keys in place.
- 11.2. Do not leave tools, materials, or trash unattended, unless secured in a safe manner.
- 11.3. Open fires are prohibited.

## 12. SECURITY

- 12.1. Contractor personnel are to limit fraternization with faculty, staff and students to the work of this Contractor only as necessary to coordinate activities of this Contract.
- 12.2. The Contractor is required to keep the site safe from intrusion(s) by public or College personnel. The Contractor shall notify the Owner immediately of unsafe conditions and incidents. Contractor's employees will not fraternize with occupants. If a problem occurs with a particular occupant the Contractor shall contact the Owner's designated representative.
- 12.3. The Owner and Occupants are not responsible for equipment, tools or materials lost from the result of being left unattended, misplaced or unsecured. Contractor's materials and tools are subject to theft. It is suggested that materials be kept in one location where practical and under lock and key.

## 13. SUBMITTALS

- 13.1. Submittals will be required by the technical sections of the design documents issued to the Contractor by the Owner in the contract documents. This paragraph governs the form of the required submittals.
- 13.2. Make submittals of shop drawings, product data, samples and other items required by the Contract Documents in accordance with the provisions of this paragraph, and revise and resubmit as necessary to establish compliance with the specified requirements. Prior to each submittal, carefully review and coordinate all aspects of each item being submitted. Verify that each item, and the submittal for it, conform in all respects with the specified requirements. Determine and verify field measurements, field construction criteria, catalog numbers and similar data, and conformance with specifications. By affixing the contractor's signature to each submittal, certify that this coordination has been performed.
- 13.3. Begin no fabrication or work which requires submittals until return of submittals with Architect's approval.

## 14. SHOP DRAWINGS

- 14.1. Shop Drawings will be submitted for approval when required by the technical section(s) of the contract documents.
- 14.2. Shop Drawings will include fabrication, erection, and setting drawings, schedule drawings, manufacturer's scale drawings, wiring and control diagrams, cut sheets of products, entire catalogs, pamphlets, descriptive literature, and performance and test data.

- 14.3. Shop Drawing(s), other than printed materials, (i.e. catalogs, pamphlets, etc.) shall be submitted in form approved by Owner. Upon approval, any reproducible shop drawing will be returned to the Contractor, who will then distribute to subcontractor(s) and manufacturer(s) as necessary and two "approved" print copies to Owner.
- 14.4. The Contractor shall allow ten working days for approval of all shop drawings. Sprinkler shop drawings, if applicable to the project, should be submitted to the Division of State Fire Marshall for their review and approval as required by codes and laws.
- 14.5. Make shop drawings accurately to a scale sufficiently large to show all pertinent aspects of the item and its method of connection to the work.
- 14.6. If not specified otherwise for a particular item or a particular division in the technical specifications submit shop drawings in the form of one sepia transparency of each sheet. Blueprints only will not be acceptable. Review comments by the Architect will be shown on the sepia transparency when it is returned to the Contractor. The Contractor may make and distribute such copies as are required for his purpose.

## **15. MANUFACTURERS' LITERATURE (PRODUCT DATA)**

- 15.1. The Contractor shall clearly show which portions of the data sheet contents are being submitted for review, especially when contents of submitted literature from manufacturers includes data not pertinent to the submittal.
- 15.2. The Contractor shall modify the manufacturer's standard schematic drawings and diagrams to delete information that is not applicable to the Work. Supplement standard information to provide information specifically applicable to the Work.
- 15.3. If not specified otherwise for a particular item or a particular division in the technical specifications, submit the number of copies that are required to be returned, plus two copies that will be retained by the Architect. Coordination Drawings: Coordination Drawings are required where work of trades involves scheduling sequences of materials, finishes or testing when necessary for proper coordination of trades, timely progress of the work or necessary sequencing of work by time, by area or by trade for the convenience of the occupants, if indicated by the Owner.

## **16. SAMPLES**

- 16.1. If not specified otherwise for a particular item or a particular division in the technical specifications, submit required samples, free of all charges and encumbrances, at the Architect's office, the Owner's office, the project site, or the Owner's warehouse, as arranged with the Architect in each instance. Sample shall be accurate in every detail as a representation of the finished article in the Work, and shall be retained by the Architect for duration of the Work. Upon completion, arrange to have the sample picked up at no expense to the Architect or to the Owner and removed from the Architect's or Owner's premises.

- 16.2. The Contractor shall accompany each submittal with a letter of transmittal showing all information required for identification and checking, and listing all deviations from the requirements of the Contract Documents. Also list all changes in the Work required to accommodate any deviations proposed in the submittal.
- 16.3. Approval by the Architect does not relieve the Contractor from responsibility for errors that may exist in the submittal, or for deviations which are not specifically listed prior to approval.
- 16.4. Any changes in the Work required to accommodate deviations from the Contract Documents shall be made at no additional cost to the Owner unless specifically approved by a Change order issued in conjunction with approval of the deviation
- 16.5. The Contractor shall deliver all submittals to the Architect for consideration as soon as possible after award of Contract.
- 16.6. The Contractor shall make submittals of all related materials and equipment at the same time.

## 17. WORKMANSHIP

- 17.1. State design and construction must comply with the codes and standards, along with their published errata and other requirements listed in this Chapter. If there is any conflict between the codes, standards, and/or regulations listed herein, the more stringent requirement controls. Designers and Agency reviewers should ensure they have the latest errata for indicated editions to International Codes, other codes and standards.
- 17.2. Codes editions in force at the time of first submittal govern throughout the project, unless: (1) Otherwise permitted by OSE; or (2) Design is delayed for more than 6 months and OSE adopts editions that are more current in the interim. No project may use a code that is older than one previous adopted edition.
- 17.3. In accordance with SC Code Ann §§ 1-34-10 thru 70 & § 10-1-180, OSE has adopted the following codes:
  - A. International Building Code (IBC), 2018 Edition,
  - B. International Existing Building Code (IEBC), 2018 Edition,
  - C. International Fire Code (IFC), 2018 Edition,
  - D. International Energy Conservation Code (IECC), 2009 Edition,
  - E. International Fuel Gas Code (IFGC), 2018 Edition,
  - F. International Mechanical Code (IMC), 2018 Edition,
  - G. International Plumbing Code (IPC), 2018 Edition, with the following insertions:
    1. Section 305.4.1, insert "18" and insert "18"
    2. Section 903.1, insert "8"
  - H. International Private Sewage Disposal Code (IPSDC), 2018 Edition,
  - I. International Property Maintenance Code (IPMC), 2018 Edition,
  - J. International Residential Code for One and Two Family Dwellings (IRC), 2018 Edition, with the following insertions: 1. P2603.5.1, insert "12" and insert "24"
  - K. International Wildland – Urban Interface Code (IUWIC), 2018 Edition,  
Note: The IUWIC does not supersede existing statutory requirements.



- L. International Code Council Performance Code (ICCPC), 2018 Edition, upon State Engineer's approval.
- M. International Swimming Pool and Spa Code (ISPSC), 2018 Edition,
- N. Standard for Bleachers, Folding and Telescopic Seating, and Grandstands, ICC 300-2017 Edition
- O. National Electrical Code (NEC) [NFPA-70], 2017 Edition
- P. National Electrical Safety Code, IEEE-C2-2017 Edition
- Q. Latest edition of the ICC A117.1, Accessible and Useable Buildings and Facilities. Note that this is the standard adopted by the South Carolina Accessibility Act, but this requirement does not relieve the Agency or the design professional from the Federal Statutory requirements that design and construction comply with the Americans with Disabilities Act Accessibility Guidelines for Buildings and Facilities. See <http://www.accessboard.gov/guidelines-and-standards/buildings-and-sites/about-the-ada-standards/ada-standards>.
- R. State Fire Marshal rules, regulations, and policies. See <http://www.scfiremarshal.llronline.com>
- S. South Carolina Elevator, Code, & Regulations. [1]: See <http://www.llr.state.sc.us/Labor/ElevatorAmusement/index.asp?file=bungee.htm>
- T. State of SC Telephone Equipment Room and Communications/Data Systems Policies as formulated by the Division of State Information Technology (DSIT).
- U. Governors executive Order No. 82-19 (April 1982) – State of SC Building Standards in Floodplain Areas.
- V. The South Carolina Modular Buildings Construction Act S.C. Code § 23-43-10 et. Seq.
- 17.4. All items shall be installed in a workmanlike manner in accordance with best-recognized practice in the field concerned. Manufactured items shall be installed in strict accordance with manufacturer's printed directions, specifications, and/or recommendations for an installation of highest quality. All working parts shall be properly adjusted after installation and be left in perfect working order. Unless otherwise indicated, items exposed to weather, or subject to flooding or wetting shall be installed so as to shed and not hold water. Items shall in all cases be installed plumb and true and/or in a proper relationship to surrounding materials.
- 17.5. The State Engineer shall determine the enforcement and interpretation of all the codes and referenced standards on State Buildings.

## 18. PROGRESS INSPECTIONS

- 18.1. The Contractor shall notify Architect prior to covering up any work. Provide adequate time notification for an inspection with the Architect's representative.
- 18.2. The Contractor shall provide labor, tools, and materials for immediate correction of any discrepancy noted at the time of the inspection.

- 18.3. The Contractor shall correct deficiencies and have the work found deficient re-inspected prior to covering up the work inspected.

## 19. RECORD DOCUMENTS

- 19.1. Contractor shall maintain one set of plans and specifications onsite in a secure area that is protected from deterioration or loss. Job set of blue or black line white-prints of contract drawings, shop drawings shall be kept clean and undamaged and presentable for scanning/reproduction. The Contractor shall provide access to the record documents for the Architect and Owner's reference during normal working hours.
- 19.2. Record Product data and Record Maintenance Manuals collectively shall show name, address and telephone number (if available) of the manufacturer and supplier of every non-generic item used in the Work, as well as the names, addresses, telephone number, and person to contact for every subcontractor, fabricator, and supplier used in the Work, together with the specific nature of the work performed or supplies furnished by each. One complete set of approved Record Product data submittals will be required. Three sets of Maintenance Manuals will be required; two shall be complete but the third need not duplicate submittals in the record product data submittal.
- 19.3. Mark the job set to show the actual installation where the installation varies substantially from the Work as originally shown. Mark whichever drawing is most capable of showing conditions fully and accurately; where shop drawings are used, record a cross-reference at the corresponding location on the contract drawings. Give particular attention to concealed elements that would be difficult to measure and record at a later date. Post changes within 24 hours, or before work is covered up. Mark job sets with colored erasable pencil; use various colors to distinguish between variations in separate categories of the work. Mark new information that is important to the Owner, but was not shown on contract drawings or shop drawings. Note related change order numbers where applicable. As-built drawings include but are limited to; site work, civil, architectural, mechanical, electrical, plumbing, fire protection, communication, ventilation, etc.
- 19.4. Show job set of record drawings, by dimension accurate to within one inch, the actual location of all elements of the Work (such as but not limited to piping, conduit, terminal boxes, etc.) concealed underground or in construction, referenced to visible and accessible features of the structure or permanent surface improvements. Include items above ceilings. Clearly identify the item by accurate note.
- 19.5. The Architect and/or Owner will inspect the final as-built drawings for accuracy and neatness.
- 19.6. If changes to the as-built drawings are required, the Architect and/or Owner will return them to the Contractor with a list of the required changes. Make required changes and promptly deliver the final project record drawings to the Architect/Owner.
- 19.7. Maintain one complete copy of the project manual, including addenda, and one copy of other written construction documents such as change orders and modifications issued in printed form during construction. Mark these documents to show substantial variations in actual work performed in comparison with the rest of the Specifications and modifications. Give particular attention to substitutions, selection of options and similar information on elements that are concealed or cannot otherwise be readily discerned later by direct observation. Note related record drawings information and

product data. Upon completion of the Work, submit record Specifications to the Architect/Owner for the Owner's records.

- 19.8. Maintain one copy of each product data submittal. Mark these documents to show significant variations in the actual Work performed in comparison with information submitted. Include variations in products delivered to the site, and from the manufacturer's installation instructions and recommendations. Give particular attention to concealed products and portions of the Work which cannot otherwise be readily discerned later by direct observation. Note related Change orders and mark-up of record drawings and Specifications. Upon completion of mark-up, submit complete set of record Product data to the Architect/Owner for the Owner's records.
- 19.9. These requirements shall be observed as minimum requirements for maintenance manuals required in this and other sections of the specifications. Additional requirements imposed by other sections shall be observed as to the specific section by which imposed. The requirements imposed by this and other sections do not require separate sets of manuals in order to satisfy both; submit the minimum number of manuals required to comply with the most demanding and include all information needed to comply with both.
- 19.10. Organize operating and maintenance data into suitable sets of manageable size. Bind properly indexed data in individual heavy-duty 3-ring vinyl-covered binders of proper capacity, with pocket folders for folded sheet information. Mark appropriate identification on front and spine of each binder. Include the following types of information:
  - A) Manufacturer's name and address,
  - B) Supplier's name and address,
  - C) Model number of each item included,
  - D) All nameplate data for each item; identify item by use/location for each nameplate for multiple items; show for each nameplated component of item,
  - E) Spare parts list,
  - F) Copies of warranties,
  - G) Wiring diagrams,
  - H) Shop Drawings and Product data,
  - I) Fixture lamping schedule,
  - J) Filter schedule,
  - K) Inspection procedures,
  - L) All applicable maintenance procedures,
  - M) All recommended maintenance cycles,
  - N) All operating procedures, and
  - O) Emergency instructions.
- 19.11. Provide three copies of each maintenance manual including all such pertinent information as is applicable, collectively including each item of equipment or material installed in the Work which can be operated and/or maintained, or, if non-generic, replaced.

## 20. CLEANING

- 20.1. Store items in an orderly arrangement and in a place suitable to the Owner. Daily, and more often if necessary, restack, tidy, or otherwise service stored materials to maintain orderly arrangement.
- 20.2. Maintain the site in a neat and orderly condition at all times. Do not allow accumulation of scrap, debris, waste material, or other items not required for this work.
- 20.3. Provide suitable containers for trash of any nature generated by the Contractor's operations or his personnel and dispose of said trash daily. Immediately recover any such trash carried or blown beyond the site of the work. Owner's trash cans and dumpsters are not for Contractor's use. All waste materials and trash shall be disposed of off-campus.
- 20.4. Contractor's personnel shall ensure their routes of travel and College-owned facilities, especially sidewalks, floors, door handles, fixtures, etc., are not inordinately fouled by substances such as grease, mud, tar, etc., which makes use of the facility less pleasant for others. Immediately clean up any such substances resulting from Contractor's presence. Cleaning by Owner, if necessary, will be done without further notice. Damage which requires a special effort on the Owner's part to clean up, repair, or replace will be at the Contractor's expense.
- 20.5. Remove all leftover materials, waste, scrap and debris generated by Contractor or his personnel.
- 20.6. Remove all traces of soil, grease, mastic, waste materials, adhesives, dust, dirt, and other foreign materials from sight-exposed surfaces.

## 21. PROTECTION OF EXISTING PROPERTY

- 21.1. The Contractor shall be responsible for all damages caused by the Contractor, the Contractor's subcontractors, or the Contractor's or subcontractors' suppliers, suppliers' shippers, and/or delivery men to trees, shrubs, sod, soil, utilities, buildings, sidewalks, gates, roadways, bodies of water, or any other property of the Owner.
- 21.2. The Contractor shall remedy damages by returning the property to its "pre- construction" state. Any College property damaged shall be repaired, reconstructed, or replaced by the Contractor or at the Contractor's expense to quality standards set by the Architect.
- 21.3. Damages which disrupt the Owner's conduct of business or the usefulness of Owner's facilities which remain in use during the term of this Contract shall be repaired immediately, as an emergency, or as otherwise approved by the Owner,
- 21.4. If the Contractor does not diligently pursue repairs to damaged property, the Owner may pursue repairs by the Owner's own forces or by another contract. All costs incurred by the Owner pursuant to such repairs will be passed on to the Contractor by Change order.
- 21.5. The Architect shall make the final determination as to the acceptability of the results of any action necessary by the Contractor to return the property to its "pre- construction" state.
- 21.6. Guarantee under the Contractor's General Warranty any property replaced or repaired by the Contractor.

## 22. OPERATING AND MAINTENANCE INSTRUCTIONS

22.1. Prior to Substantial Completion arrange for each installer of equipment that requires operation or regular maintenance to meet with the Owner's personnel to provide instruction in proper operation and maintenance. If installers are not experienced in procedures, provide instruction by manufacturer's representatives. Provide adequate time for proper instruction. Do not short-schedule too many too close together. Include a detailed review of each of the following items which is applicable:

- A) Maintenance manuals,
- B) Record documents,
- C) Spare parts and materials,
- D) Tools,
- E) Lubricants,
- F) Fuels,
- G) Identification systems,
- H) Control sequences,
- I) Hazards,
- J) Cleaning,
- K) Warranties and bonds,
- L) Maintenance agreements and similar continuing commitments, and
- M) Other items/matters applicable to the item in question.

22.2. As part of instruction for operating equipment, demonstrate each of the following procedures which is applicable:

- A) Start-up,
- B) Shut down,
- C) All operating adjustments and procedures,
- D) All maintenance procedures,
- E) All diagnostic procedures,
- F) Emergency operations,
- G) Safety procedures,
- H) Noise and vibration adjustments,
- I) Economy and efficiency adjustments,
- J) Effective energy utilization, and
- K) Other procedures applicable to the item in question.

## 23. SUBSTANTIAL COMPLETION

23.1. Substantial Completion requires all materials and equipment to be installed and operational to the extent the Owner can use the Work for its intended purpose.

23.2. When the Contractor feels the project is substantially complete, the Contractor shall notify the Architect and the Owner in writing.

23.3. Within a reasonable time after receipt of the list, the Architect will inspect to determine status of completion.

- 23.4. Should the Architect determine that the work is not substantially complete the Architect promptly will so notify the Contractor.
- 23.4.1 The Contractor shall remedy the deficiencies and notify the Architect when ready for re-inspection.
- 23.4.2 The Architect will re-inspect the Work.
- 23.5. When the Architect concurs that the work is substantially complete:
  - 23.5.1 The Architect will prepare a "Certificate of Substantial Completion" on AIA Form G704, accompanied by the Contractor's list of items to be completed or corrected, as verified by the Architect.
  - 23.5.2 The Architect will submit the Certificate to the Owner and to the Contractor for their written acceptance of the responsibilities assigned to them in the Certificate.

## 24. FINAL COMPLETION

- 24.1. Final Completion shall be achieved no later than thirty (30) days after Substantial Completion, unless a later date is established on the Certificate of Substantial Completion.
- 24.2. When the Contractor corrects all deficiencies on the punch list generated from the Substantial Completion Inspection Section above, the Contractor shall notify the Architect and Owner in writing.
- 24.3. Before notifying the Architect of Final Completion status, certify that:
  - 24.3.1 The Contract Documents have been reviewed.
  - 24.3.2 Work has been inspected for compliance with the Contract Documents.
  - 24.3.3 Work has been completed in accordance with the Contract Documents.
  - 24.3.4 All systems have been tested and are operational.
  - 24.3.5 Work is completed and ready for final inspection.
- 24.4. The Architect will make an inspection to verify status of completion.
- 24.5. Should the Architect determine that the work is incomplete or defective:
  - 24.5.1 The Architect promptly will so notify the Contractor.
  - 24.5.2 The Contractor shall remedy the deficiencies promptly, and notify the Architect when ready for re-inspection.
  - 24.5.3 The Architect will re-inspect the work.
- 24.6. When the Architect determines that the work is acceptable under the Contract Documents the Architect will request the Contractor to make closeout submittals.

## 25. CLOSEOUT SUBMITTALS

- 25.1. Before applying for final payment, furnish to the Owner:
- 25.2. A hard-backed binder (3-hole punch/tabbed binder) containing the following:

- A) A typewritten materials list, in triplicate, showing every manufacturer item/material used in the job. Include catalog number, manufacturer's name and address, distributor's name and address. Type lists neatly and index according to respective specification sections of work,
- B) A list of all subcontractors, including fabricators, used in the work, and the nature of the work performed by each. Show company name, address, and telephone number. If Company has more than one office, show data for the office handling the work and the home office,
- C) A properly executed Contractor's General Warranty form, and
- D) All other warranties, forms, certifications, and other documents required by the technical specifications.

25.3. Project Record Documents described within these General Requirements.

25.4. All keys and control or security components that are not a permanent part of installed equipment.

## **26. WARRANTY**

- 26.1. The Contractor warrants to Owner that materials and equipment furnished under the Contract will be of good quality and new unless otherwise required or permitted by the Contract Documents, that the Work will conform with the requirements of the Contract Documents. Work not conforming to these requirements, including substitutions not properly approved and authorized, may be considered defective. The Contractor's warranty excludes remedy for damage or defect caused by abuse, modifications not executed by the Contractor, improper or insufficient maintenance, improper operation, or normal wear and tear under normal usage. If required by the Owner, the Contractor shall furnish satisfactory evidence as to the kind and quality of materials and equipment.
- 26.2. The period of the warranty shall be for one year (365 calendar days) from the date of Substantial Completion for all work described in the contract documents and any approved change orders. The Contractor is required to honor any special warranties which may be required in the scope of work as described in the specifications and contract documents.

## SECTION 080671 – DOOR HARDWARE SCHEDULE

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. This Section references specification sections relating to commercial door hardware for the following:
  - 1. Swinging doors.
  - 2. Other doors to the extent indicated.
- B. Commercial door hardware includes, but is not necessarily limited to, the following:
  - 1. Mechanical door hardware.
  - 2. Electromechanical and access control door hardware.
  - 3. Electromechanical and access control door hardware power supplies, back-ups and surge protection.
  - 4. Cylinders specified for doors in other sections.
- C. Related Sections:
  - 1. Division 08 Section “Door Hardware”.
- D. Codes and References: Comply with the version year adopted by the Authority Having Jurisdiction.
  - 1. ANSI A117.1 - Accessible and Usable Buildings and Facilities.
  - 2. ICC/IBC - International Building Code.
  - 3. NFPA 70 - National Electrical Code.
  - 4. NFPA 80 - Fire Doors and Windows.
  - 5. NFPA 101 - Life Safety Code.
  - 6. NFPA 105 - Installation of Smoke Door Assemblies.
  - 7. State Building Codes, Local Amendments.
- E. Standards: Reference Related Sections for requirements regarding compliance with applicable industry standards.



### 1.3 SUBMITTALS

- A. Product Data: Manufacturer's product data sheets including installation details, material descriptions, dimensions of individual components and profiles, operational descriptions and finishes.
- B. Door Hardware Schedule: Prepared by or under the supervision of supplier, detailing fabrication and assembly of door hardware, as well as procedures and diagrams. Coordinate the final Door Hardware Schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of door hardware.
  - 1. Format: Comply with scheduling sequence and vertical format in DHI's "Sequence and Format for the Hardware Schedule."
  - 2. Organization: Organize the Door Hardware Schedule into door hardware sets indicating complete designations of every item required for each door or opening. Organize door hardware sets in same order as in the Door Hardware Sets at the end of Part 3. Submittals that do not follow the same format and order as the Door Hardware Sets will be rejected and subject to resubmission.
  - 3. Content: Include the following information:
    - a. Type, style, function, size, label, hand, and finish of each door hardware item.
    - b. Manufacturer of each item.
    - c. Fastenings and other pertinent information.
    - d. Location of door hardware set, cross-referenced to Drawings, both on floor plans and in door and frame schedule.
    - e. Explanation of abbreviations, symbols, and codes contained in schedule.
    - f. Mounting locations for door hardware.
    - g. Door and frame sizes and materials.
  - 4. Submittal Sequence: Submit the final Door Hardware Schedule at earliest possible date, particularly where approval of the Door Hardware Schedule must precede fabrication of other work that is critical in the Project construction schedule. Include Product Data, Samples, Shop Drawings of other work affected by door hardware, and other information essential to the coordinated review of the Door Hardware Schedule.
- C. Keying Schedule: Prepared under the supervision of the Owner, separate schedule detailing final keying instructions for locksets and cylinders in writing. Include keying system explanation, door numbers, key set symbols, hardware set numbers and special instructions. Owner to approve submitted keying schedule prior to the ordering of permanent cylinders.
- D. Product Test Reports: Indicating compliance with cycle testing requirements, based on evaluation of comprehensive tests performed by manufacturer and witnessed by a qualified independent testing agency.
- E. Operating and Maintenance Manuals: Provide manufacturers operating and maintenance manuals for each item comprising the complete door hardware installation in quantity as required in Division 01, Closeout Submittals. The manual to include the name, address, and

contact information of the manufacturers providing the hardware and their nearest service representatives. The final copies delivered after completion of the installation test to include "as built" modifications made during installation, checkout, and acceptance.

- F. Warranties and Maintenance: Special warranties and maintenance agreements specified in the Related Sections.

#### 1.4 DELIVERY, STORAGE, AND HANDLING

- A. Inventory door hardware on receipt and provide secure lock-up and shelving for door hardware delivered to Project site. Do not store electronic access control hardware, software or accessories at Project site without prior authorization.
- B. Tag each item or package separately with identification related to the final Door Hardware Schedule, and include basic installation instructions with each item or package.
- C. Deliver, as applicable, permanent keys, cylinders, cores, access control credentials, software and related accessories directly to Owner via registered mail or overnight package service. Instructions for delivery to the Owner shall be established at the "Keying Conference".

#### 1.5 WARRANTY

- A. General Warranty: Reference Division 01, General Requirements. Special warranties specified in this Article shall not deprive Owner of other rights Owner may have under other provisions of the Contract Documents and shall be in addition to, and run concurrent with, other warranties made by Contractor under requirements of the Contract Documents.

#### 1.6 MAINTENANCE SERVICE

- A. Maintenance Tools and Instructions: Furnish a complete set of specialized tools and maintenance instructions as needed for Owner's continued adjustment, maintenance, and removal and replacement of door hardware.

### PART 2 - PRODUCTS

#### 2.1 SCHEDULED DOOR HARDWARE

- A. Refer to "PART 3 – EXECUTION" for required specification sections.

### PART 3 - EXECUTION

#### 3.1 DOOR HARDWARE SETS

- A. The door hardware sets represent the design intent and direction of the owner and architect. They are a guideline only and should not be considered a detailed hardware schedule.

Discrepancies, conflicting hardware and missing items should be brought to the attention of the architect with corrections made prior to the bidding process. Omitted items not included in a hardware set should be scheduled with the appropriate additional hardware required for proper application and functionality.

1. Quantities listed are for each pair of doors, or for each single door.
2. The supplier is responsible for handing and sizing all products.
3. Where multiple options for a piece of hardware are given in a single line item, the supplier shall provide the appropriate application for the opening.
4. At existing openings with new hardware the supplier shall field inspect existing conditions prior to the submittal stage to verify the specified hardware will work as required. Provide alternate solutions and proposals as needed.

B. The hardware sets represent the design intent and direction of the owner and architect. They are a guideline only and should not be considered a detailed hardware schedule. Discrepancies, conflicting hardware and missing items should be brought to the attention of the architect with corrections made prior to the bidding process. Omitted items not included in a hardware set should be scheduled with the appropriate additional hardware required for proper application and functionality.

1. Quantities listed are for each pair of doors, or for each single door.
2. The supplier is responsible for handing and sizing all products.
3. Where multiple options for a piece of hardware are given in a single line item, the supplier shall provide the appropriate application for the opening.

C. Manufacturer's Abbreviations:

1. MK - McKinney
2. PE - Pemko
3. RO - Rockwood
4. SA - SARGENT
5. SU - Securitron
6. HD - HID

### **Hardware Sets**

#### **Set: 1.0**

Doors: 101

Description: Aluminum Card Access Exit Pair

1	Continuous Hinge	CFM__HD1 x Door height		PE
1	Continuous Hinge	CFM__HD1 SER12 x Door Height		PE ↗
1	Mullion	L980A	US28	SA
1	Rim Exit Device, Storeroom	55 56 72 AD8504	US32D	SA ↗
1	Rim Exit Device, Dummy	LD AD8510	US32D	SA
2	Magnetic Lock W/ REX	M680EBDX		SU ↗
1	Mortise Cylinder SFIC	72 41	US15	SA
1	Small Format Inter Core	11-7300B	US15	SA
2	Offset Door Pull	RM3311-24 Mtg-Type 1	US32D	RO
2	Drop Plate	351D	EN	SA
2	Surface Closer	TB 351 CPS 581-2	EN	SA
1	Threshold	171AK x Opening width		PE
2	Sweep	315CN x Door Width		PE
1	Astragal	357C x Door Height		PE
1	Wall MultiClass Reader	SE RP40	BLK	HD ↗
1	Motion Sensor	XMS		SU ↗
1	Push Button	EEB2		SU ↗
1	Position Switch	DPS-M-GY		SU ↗
1	Power Supply	AQD Series as Required		SU ↗

Notes: Perimeter gasket by frame manufacturer.

Door controller and security management software by others.

OPERATION: Card reader outside, emergency exit button, PIR motion sensor or remote release inside temporarily unlock magnetic lock. Lock can be put into passage mode by door system controller. Mag lock is fail-safe with door position sensor & status sensor.

Mechanical locks are for prolonged power outage, etc.

**Set: 2.0**

Doors: 102

Description: Entrance/Office Function + Closer

3	Hinge, Full Mortise	TA2714	US26D	MK
1	Entrance/Office Lock	72 10XG05 LL	US26D	SA
1	Small Format Inter Core	11-7300B	US15	SA
1	Surface Closer	351 O	EN	SA
1	Mop Plate	K1050 6" High CSK	US32D	RO
1	Kick Plate	K1050 10" High CSK	US32D	RO
1	Wall Stop	406	US32D	RO
1	Adhesive Gasketing	S88BL x Head & Jambs		PE

END OF SECTION 080671

## SECTION 081213 - HOLLOW METAL FRAMES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes hollow-metal frames.
- B. Related Requirements:
  - 1. Section 081416 "Flush Wood Doors" for wood doors installed in hollow-metal frames.

#### 1.3 DEFINITIONS

- A. Minimum Thickness: Minimum thickness of base metal without coatings according to NAAMM-HMMA 803 or SDI A250.8.

#### 1.4 COORDINATION

- A. Coordinate anchorage installation for hollow-metal frames. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors. Deliver such items to Project site in time for installation.

#### 1.5 ACTION SUBMITTALS

- A. Shop Drawings: Include the following:
  - 1. Frame details for each frame type, including dimensioned profiles and metal thicknesses.
  - 2. Locations of reinforcement and preparations for hardware.
  - 3. Details of each different wall opening condition.
  - 4. Details of anchorages, joints, field splices, and connections.
  - 5. Details of moldings, removable stops, and glazing.
  - 6. Details of conduit and preparations for power, signal, and control systems.
- B. Schedule: Provide a schedule of hollow-metal work prepared by or under the supervision of supplier, using same reference numbers for details and openings as those on Drawings. Coordinate with final Door Hardware Schedule.

## 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Deliver hollow-metal work palletized, packaged, or crated to provide protection during transit and Project-site storage. Do not use nonvented plastic.
  - 1. Provide additional protection to prevent damage to factory-finished units.
- B. Deliver welded frames with two removable spreader bars across bottom of frames, tack welded to jambs and mullions.
- C. Store hollow-metal work vertically under cover at Project site with head up. Place on minimum 4-inch-high wood blocking. Provide minimum 1/4-inch space between each unit to permit air circulation.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Source Limitations: Obtain hollow-metal work from single source from single manufacturer.

### 2.2 INTERIOR FRAMES

- A. Construct interior frames to comply with the standards indicated for materials, fabrication, hardware locations, hardware reinforcement, tolerances, and clearances, and as specified.
- B. Heavy-Duty Frames: SDI A250.8, Level 2.
  - 1. Physical Performance: Level B according to SDI A250.4.
  - 2. Materials: Metallic-coated steel sheet, minimum thickness of 0.053 inch.
  - 3. Construction: Face welded.
  - 4. Exposed Finish: Prime.

### 2.3 FRAME ANCHORS

- A. Jamb Anchors:
  - 1. Stud-Wall Type: Designed to engage stud, welded to back of frames; not less than 0.042 inch thick.
- B. Floor Anchors: Formed from same material as frames, minimum thickness of 0.042 inch, and as follows:
  - 1. Monolithic Concrete Slabs: Clip-type anchors, with two holes to receive fasteners.

### 2.4 MATERIALS

- A. Cold-Rolled Steel Sheet: ASTM A 1008/A 1008M, Commercial Steel (CS), Type B; suitable for exposed applications.

- B. Hot-Rolled Steel Sheet: ASTM A 1011/A 1011M, Commercial Steel (CS), Type B; free of scale, pitting, or surface defects; pickled and oiled.
- C. Metallic-Coated Steel Sheet: ASTM A 653/A 653M, Commercial Steel (CS), Type B.
- D. Frame Anchors: ASTM A 879/A 879M, Commercial Steel (CS), 04Zcoating designation; mill phosphatized.
- E. For anchors built into exterior walls, steel sheet complying with ASTM A 1008/A 1008M or ASTM A 1011/A 1011M, hot-dip galvanized according to ASTM A 153/A 153M, Class B.
- F. Inserts, Bolts, and Fasteners: Hot-dip galvanized according to ASTM A 153/A 153M.

## 2.5 FABRICATION

- A. Fabricate hollow-metal work to be rigid and free of defects, warp, or buckle. Accurately form metal to required sizes and profiles, with minimum radius for metal thickness. Where practical, fit and assemble units in manufacturer's plant. To ensure proper assembly at Project site, clearly identify work that cannot be permanently factory assembled before shipment.
- B. Hollow-Metal Frames: Where frames are fabricated in sections due to shipping or handling limitations, provide alignment plates or angles at each joint, fabricated of same thickness metal as frames.
  - 1. Provide countersunk, flat- or oval-head exposed screws and bolts for exposed fasteners unless otherwise indicated.
  - 2. Floor Anchors: Weld anchors to bottoms of jambs with at least four spot welds per anchor; however, for slip-on drywall frames, provide anchor clips or countersunk holes at bottoms of jambs.
  - 3. Jamb Anchors: Provide number and spacing of anchors as follows:
    - a. Masonry Type: Locate anchors not more than 16 inches from top and bottom of frame. Space anchors not more than 32 inches o.c., to match coursing, and as follows:
      - 1) Two anchors per jamb up to 60 inches high.
      - 2) Three anchors per jamb from 60 to 90 inches high.
      - 3) Four anchors per jamb from 90 to 120 inches high.
      - 4) Four anchors per jamb plus one additional anchor per jamb for each 24 inches or fraction thereof above 120 inches high.
    - b. Stud-Wall Type: Locate anchors not more than 18 inches from top and bottom of frame. Space anchors not more than 32 inches o.c. and as follows:
      - 1) Three anchors per jamb up to 60 inches high.
      - 2) Four anchors per jamb from 60 to 90 inches high.
      - 3) Five anchors per jamb from 90 to 96 inches high.
      - 4) Five anchors per jamb plus one additional anchor per jamb for each 24 inches or fraction thereof above 96 inches high.



- C. Hardware Preparation: Factory prepare hollow-metal work to receive templated mortised hardware; include cutouts, reinforcement, mortising, drilling, and tapping according to SDI A250.6, the Door Hardware Schedule, and templates.
  - 1. Reinforce frames to receive nontemplated, mortised, and surface-mounted hardware.
  - 2. Comply with applicable requirements in SDI A250.6 and BHMA A156.115 for preparation of hollow-metal work for hardware.
- D. Stops and Moldings: Provide stops and moldings around glazed lites and louvers where indicated. Form corners of stops and moldings with butted or mitered hairline joints.
  - 1. Single Glazed Lites: Provide fixed stops and moldings welded on secure side of hollow-metal work.
  - 2. Multiple Glazed Lites: Provide fixed and removable stops and moldings so that each glazed lite is capable of being removed independently.
  - 3. Provide fixed frame moldings on outside of exterior and on secure side of interior frames.
  - 4. Provide loose stops and moldings on inside of hollow-metal work.
  - 5. Coordinate rabbet width between fixed and removable stops with glazing and installation types indicated.

## 2.6 STEEL FINISHES

- A. Prime Finish: Clean, pretreat, and apply manufacturer's standard primer.
  - 1. Shop Primer: Manufacturer's standard, fast-curing, lead- and chromate-free primer complying with SDI A250.10; recommended by primer manufacturer for substrate; compatible with substrate and field-applied coatings despite prolonged exposure.
- B. Factory Finish: Clean, pretreat, and apply manufacturer's standard two-coat, baked-on finish consisting of prime coat and thermosetting topcoat, complying with SDI A250.3.
  - 1. Color and Gloss: As selected by Architect from manufacturer's full range.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine roughing-in for embedded and built-in anchors to verify actual locations before frame installation.
- C. Prepare written report, endorsed by Installer, listing conditions detrimental to performance of the Work.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Remove welded-in shipping spreaders installed at factory. Restore exposed finish by grinding, filling, and dressing, as required to make repaired area smooth, flush, and invisible on exposed faces.
- B. Drill and tap frames to receive nontemplated, mortised, and surface-mounted hardware.

### 3.3 INSTALLATION

- A. General: Install hollow-metal work plumb, rigid, properly aligned, and securely fastened in place. Comply with Drawings and manufacturer's written instructions.
- B. Hollow-Metal Frames: Install hollow-metal frames of size and profile indicated. Comply with SDI A250.11 or NAAMM-HMMA 840 as required by standards specified.
  - 1. Set frames accurately in position; plumbed, aligned, and braced securely until permanent anchors are set. After wall construction is complete, remove temporary braces, leaving surfaces smooth and undamaged.
    - a. Where frames are fabricated in sections because of shipping or handling limitations, field splice at approved locations by welding face joint continuously; grind, fill, dress, and make splice smooth, flush, and invisible on exposed faces.
    - b. Install frames with removable stops located on secure side of opening.
    - c. Remove temporary braces necessary for installation only after frames have been properly set and secured.
    - d. Check plumb, square, and twist of frames as walls are constructed. Shim as necessary to comply with installation tolerances.
  - 2. Floor Anchors: Provide floor anchors for each jamb and mullion that extends to floor, and secure with postinstalled expansion anchors.
    - a. Floor anchors may be set with power-actuated fasteners instead of postinstalled expansion anchors if so indicated and approved on Shop Drawings.
  - 3. Metal-Stud Partitions: Solidly pack mineral-fiber insulation inside frames.
  - 4. Masonry Walls: Coordinate installation of frames to allow for solidly filling space between frames and masonry with grout.
  - 5. Installation Tolerances: Adjust hollow-metal door frames for squareness, alignment, twist, and plumb to the following tolerances:
    - a. Squareness: Plus or minus 1/16 inch, measured at door rabbet on a line 90 degrees from jamb perpendicular to frame head.
    - b. Alignment: Plus or minus 1/16 inch, measured at jambs on a horizontal line parallel to plane of wall.
    - c. Twist: Plus or minus 1/16 inch, measured at opposite face corners of jambs on parallel lines, and perpendicular to plane of wall.
    - d. Plumbness: Plus or minus 1/16 inch, measured at jambs at floor.

- C. Glazing: Comply with installation requirements in Section 088000 "Glazing" and with hollow-metal manufacturer's written instructions.
  - 1. Secure stops with countersunk flat- or oval-head machine screws spaced uniformly not more than 9 inches o.c. and not more than 2 inches o.c. from each corner.

#### 3.4 ADJUSTING AND CLEANING

- A. Final Adjustments: Remove and replace defective work, including hollow-metal work that is warped, bowed, or otherwise unacceptable.
- B. Remove grout and other bonding material from hollow-metal work immediately after installation.
- C. Prime-Coat Touchup: Immediately after erection, sand smooth rusted or damaged areas of prime coat and apply touchup of compatible air-drying, rust-inhibitive primer.
- D. Touchup Painting: Cleaning and touchup painting of abraded areas of paint are specified in painting Sections.

END OF SECTION 081213

## SECTION 081416 - FLUSH WOOD DOORS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:

1. Solid-core doors with faces.
2. Factory finishing flush wood doors.
3. Factory fitting flush wood doors to frames and factory machining for hardware.

- B. Related Requirements:

1. Section 081213 "Hollow Metal Frames" for interior custom hollow-metal frames.
2. Section 099123 "Interior Painting", for field finishing doors.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of door. Include details of core and edge construction and trim for openings. Include factory-finishing specifications.

- B. Shop Drawings: Indicate location, size, and hand of each door; elevation of each kind of door; construction details not covered in Product Data; and the following:

1. Door schedule indicating door location, type, size, fire protection rating, and swing.
2. Door elevations, dimension and locations of hardware, lite and louver cutouts, and glazing thicknesses.
3. Details of frame for each frame type, including dimensions and profile.
4. Dimensions and locations of blocking.
5. Dimensions and locations of mortises and holes for hardware.
6. Dimensions and locations of cutouts.
7. Undercuts.
8. Doors to be factory finished and finish requirements.

- C. Samples for Verification:

1. Factory finishes applied to actual door face materials, approximately 8 by 10 inches, for each material and finish. For each wood species and transparent finish, provide set of three Samples showing typical range of color and grain to be expected in finished Work.
2. Corner sections of doors, approximately 8 by 10 inches, with door faces and edges representing actual materials to be used.
  - a. Provide Samples for each species of veneer and solid lumber required.
  - b. Finish veneer-faced door Samples with same materials proposed for factory-finished doors.

#### 1.4 INFORMATIONAL SUBMITTALS

- A. Sample Warranty: For special warranty.

#### 1.5 CLOSEOUT SUBMITTALS

- A. Special warranties.

#### 1.6 QUALITY ASSURANCE

- A. Vendor Qualifications: A vendor that is certified for chain of custody by an FSC-accredited certification body.

#### 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Comply with requirements of referenced standard and manufacturer's written instructions.
- B. Package doors individually in cardboard cartons and wrap bundles of doors in plastic sheeting.
- C. Mark each door on top and bottom rail with opening number used on Shop Drawings.

#### 1.8 FIELD CONDITIONS

- A. Environmental Limitations: Do not deliver or install doors until spaces are enclosed and weathertight, wet work in spaces is complete and dry, and HVAC system is operating and maintaining temperature between 60 and 90 deg F and relative humidity between 25 and 55 percent during remainder of construction period.

#### 1.9 WARRANTY

- A. Special Warranty: Manufacturer agrees to repair or replace doors that fail in materials or workmanship within specified warranty period.
  1. Failures include, but are not limited to, the following:

- a. Warping (bow, cup, or twist) more than 1/4 inch in a 42-by-84-inch section.
  - b. Telegraphing of core construction in face veneers exceeding 0.01 inch in a 3-inch span.
2. Warranty shall also include installation and finishing that may be required due to repair or replacement of defective doors.
  3. Warranty Period for Solid-Core Exterior Doors: Five years from date of Substantial Completion.
  4. Warranty Period for Solid-Core Interior Doors: Life of installation.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. **Manufacturers:** Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  1. Algoma Hardwood, Inc.
  2. Graham: an Assa Abloy Group Company.
  3. Mohawk Flush Doors, Inc; a Masonite Company.
- B. Source Limitations: Obtain flush wood doors from single manufacturer.

### 2.2 FLUSH WOOD DOORS, GENERAL

- A. Quality Standard: In addition to requirements specified, comply with AWI's, AWMAC's, and WI's "Architectural Woodwork Standards."
- B. Particleboard-Core Doors:
  1. Particleboard: ANSI A208.1, Grade LD-1 or Grade LD-2.
  2. Blocking: Provide wood blocking in particleboard-core doors as needed to eliminate through-bolting hardware. follows:
    - a. 5-inch top-rail blocking, in doors indicated to have closers.
    - b. 5-inch bottom-rail blocking, in exterior doors and doors indicated to have kick, mop, or armor plates.
    - c. 5-inch midrail blocking, in doors indicated to have exit devices.
  3. Provide doors with glued-wood-stave or structural-composite-lumber cores instead of particleboard cores for doors indicated to receive exit devices.
- C. Structural-Composite-Lumber-Core Doors:
  1. Structural Composite Lumber: WDMA I.S.10.
    - a. Screw Withdrawal, Face: 700 lbf.

- b. Screw Withdrawal, Edge: 400 lbf.

## 2.3 VENEER-FACED DOORS FOR TRANSPARENT FINISH

### A. Interior Solid-Core Doors:

1. Grade: Premium, with Grade A faces.
2. Species: Select white maple.
3. Stain: To match existing doors, color as selected from manufacturer's full range.
4. Cut: Quarter sliced.
5. Match between Veneer Leaves: Slip match.
6. Assembly of Veneer Leaves on Door Faces: Running match.
7. Pair and Set Match: Provide for doors hung in same opening.
8. Exposed Vertical and Top Edges: Same species as faces - edge Type A.
9. Core: Glued wood stave.
10. Construction: Five plies. Stiles and rails are bonded to core, then entire unit is abrasive planed before veneering. Faces are bonded to core using a hot press.
11. Construction: Seven plies, either bonded or nonbonded construction.

## 2.4 FABRICATION

### A. Factory fit doors to suit frame-opening sizes indicated. Comply with clearance requirements of referenced quality standard for fitting unless otherwise indicated.

1. Comply with NFPA 80 requirements for fire-rated doors.

### B. Factory machine doors for hardware that is not surface applied. Locate hardware to comply with DHI-WDHS-3. Comply with final hardware schedules, door frame Shop Drawings, BHMA-156.115-W, and hardware templates.

1. Coordinate with hardware mortises in metal frames to verify dimensions and alignment before factory machining.
2. Metal Astragals: Factory machine astragals and formed-steel edges for hardware for pairs of fire-rated doors.

## 2.5 FACTORY FINISHING

### A. General: Comply with referenced quality standard for factory finishing. Complete fabrication, including fitting doors for openings and machining for hardware that is not surface applied, before finishing.

1. Finish faces, all four edges, edges of cutouts, and mortises. Stains and fillers may be omitted on top and bottom edges, edges of cutouts, and mortises.

### B. Factory finish doors.

### C. Factory finish doors that are indicated to receive transparent finish.

- D. Factory finish doors where indicated in schedules or on Drawings as factory finished.
- E. Transparent Finish:
  - 1. Grade: Premium.
  - 2. Finish: , WDMA TR-6 catalyzed polyurethane,.
  - 3. Staining: As selected by Architect from manufacturer's full range.
  - 4. Effect: Open-grain finish.
  - 5. Sheen: Satin.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine doors and installed door frames, with Installer present, before hanging doors.
  - 1. Verify that installed frames comply with indicated requirements for type, size, location, and swing characteristics and have been installed with level heads and plumb jambs.
  - 2. Reject doors with defects.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. Hardware: For installation, see Section 087100 "Door Hardware."
- B. Installation Instructions: Install doors to comply with manufacturer's written instructions and referenced quality standard, and as indicated.
- C. Factory-Fitted Doors: Align in frames for uniform clearance at each edge.
- D. Factory-Finished Doors: Restore finish before installation if fitting or machining is required at Project site.

#### 3.3 ADJUSTING

- A. Operation: Rehang or replace doors that do not swing or operate freely.
- B. Finished Doors: Replace doors that are damaged or that do not comply with requirements. Doors may be repaired or refinished if Work complies with requirements and shows no evidence of repair or refinishing.

END OF SECTION 081416



## SECTION 092216 - NON-STRUCTURAL METAL FRAMING

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Non-load-bearing steel framing systems for interior gypsum board assemblies.
  - 2. Suspension systems for interior gypsum ceilings, soffits, and grid systems.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.

#### 1.4 QUALITY ASSURANCE

- A. Code-Compliance Certification of Studs and Tracks: Provide documentation that framing members are certified according to the product-certification program by one of the following industry associations:
  - 1. Certified Steel Stud Association.
  - 2. Steel Framing Industry Association.
  - 3. Steel Stud Manufacturers Association.

### PART 2 - PRODUCTS

#### 2.1 PERFORMANCE REQUIREMENTS

- A. STC-Rated Assemblies: For STC-rated assemblies, provide materials and construction identical to those tested in assembly indicated, according to ASTM E 90 and classified according to ASTM E 413 by an independent testing agency.

#### 2.2 FRAMING SYSTEMS

- A. Framing Members, General: Comply with ASTM C 754 for conditions indicated.
  - 1. Steel Sheet Components: Comply with ASTM C 645 requirements for metal unless otherwise indicated.

2. Protective Coating: ASTM A 653/A 653M, G40, hot-dip galvanized unless otherwise indicated.
- B. Studs and Runners: ASTM C 645. Use either steel studs and runners or dimpled steel studs and runners.
1. Steel Studs and Runners:
    - a. Minimum Base-Metal Thickness: 20 gauge minimum.
    - b. Depth: As indicated on Drawings.
  2. Dimpled Steel Studs and Runners:
    - a. Minimum Base-Metal Thickness: 20 gauge minimum.
    - b. Depth: As indicated on Drawings.
- C. Hat-Shaped, Rigid Furring Channels: ASTM C 645.
1. Minimum Base-Metal Thickness: 0.018 inch.
  2. Depth: As indicated on Drawings.
- D. Slip-Type Head Joints: Where indicated, provide the following:
1. Double-Track System: ASTM C 645 top outer tracks, inside track with 2-inch-deep flanges in thickness not less than indicated for studs and fastened to studs, and outer track sized to friction-fit over inner track.
  2. Clip System: Clips designed for use in head-of-wall deflection conditions that provide a positive attachment of studs to tracks while allowing 1-1/2-inch minimum vertical movement.
  3. Single Long-Leg Track System: ASTM C 645 top track with 2-inch-deep flanges in thickness not less than indicated for studs, installed with studs friction fit into top track and with continuous bridging located within 12 inches of the top of studs to provide lateral bracing.
  4. Deflection Track: Steel sheet top track manufactured to prevent cracking of finishes applied to interior partition framing resulting from deflection of structure above; in thickness not less than indicated for studs and in width to accommodate depth of studs.
- E. Firestop Tracks: Top track manufactured to allow partition heads to expand and contract with movement of structure while maintaining continuity of fire-resistance-rated assembly indicated; in thickness not less than indicated for studs and in width to accommodate depth of studs.

## 2.3 SUSPENSION SYSTEMS

- A. Furring Channels (Furring Members):
1. Steel Studs and Runners: ASTM C 645.
    - a. Minimum Base-Metal Thickness: 0.018 inch.

- b. Depth: As indicated on Drawings.
- 2. Hat-Shaped, Rigid Furring Channels: ASTM C 645, 7/8 inch deep.
  - a. Minimum Base-Metal Thickness: 0.018 inch.
- 3. Grid Suspension System for Gypsum Board Ceilings: ASTM C 645, direct-hung system composed of main beams and cross-furring members that interlock.

## 2.4 AUXILIARY MATERIALS

- A. General: Provide auxiliary materials that comply with referenced installation standards.
  - 1. Fasteners for Metal Framing: Of type, material, size, corrosion resistance, holding power, and other properties required to fasten steel members to substrates.
- B. Shaft wall: Provide all materials per shaft wall manufacturer's standard specifications.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine areas and substrates, with Installer present, and including welded hollow-metal frames, cast-in anchors, and structural framing, for compliance with requirements and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Suspended Assemblies: Coordinate installation of suspension systems with installation of overhead structure to ensure that inserts and other provisions for anchorages to building structure have been installed to receive hangers at spacing required to support the Work and that hangers will develop their full strength.
  - 1. Furnish concrete inserts and other devices indicated to other trades for installation in advance of time needed for coordination and construction.

### 3.3 INSTALLATION, GENERAL

- A. Installation Standard: ASTM C 754.
  - 1. Gypsum Board Assemblies: Also comply with requirements in ASTM C 840 that apply to framing installation.
- B. Install supplementary framing, and blocking to support fixtures, equipment services, heavy trim, grab bars, toilet accessories, furnishings, or similar construction.
- C. Install bracing at terminations in assemblies.

- D. Do not bridge building control and expansion joints with non-load-bearing steel framing members. Frame both sides of joints independently.

### 3.4 INSTALLING FRAMED ASSEMBLIES

- A. Install framing system components according to spacings indicated, but not greater than spacings required by referenced installation standards for assembly types.
  - 1. Single-Layer Application: 16 inches o.c. unless otherwise indicated.
- B. Where studs are installed directly against exterior masonry walls or dissimilar metals at exterior walls, install isolation strip between studs and exterior wall.
- C. Install studs so flanges within framing system point in same direction.
- D. Install tracks (runners) at floors and overhead supports. Extend framing full height to structural supports or substrates above suspended ceilings except where partitions are indicated to terminate at suspended ceilings. Continue framing around ducts penetrating partitions above ceiling.
  - 1. Slip-Type Head Joints: Where framing extends to overhead structural supports, install to produce joints at tops of framing systems that prevent axial loading of finished assemblies.
  - 2. Door Openings: Screw vertical studs at jambs to jamb anchor clips on door frames; install runner track section (for cripple studs) at head and secure to jamb studs.
    - a. Install two studs at each jamb unless otherwise indicated.
  - 3. Other Framed Openings: Frame openings other than door openings the same as required for door openings unless otherwise indicated. Install framing below sills of openings to match framing required above door heads.
  - 4. Sound-Rated Partitions: Install framing to comply with sound-rated assembly indicated.
- E. Direct Furring:
  - 1. Attach to concrete or masonry with stub nails, screws designed for masonry attachment, or powder-driven fasteners spaced 24 inches o.c.
- F. Installation Tolerance: Install each framing member so fastening surfaces vary not more than 1/8 inch from the plane formed by faces of adjacent framing.

### 3.5 INSTALLING SUSPENSION SYSTEMS

- A. Install suspension system components according to spacings indicated, but not greater than spacings required by referenced installation standards for assembly types.
  - 1. Hangers: 48 inches o.c.

2. Furring Channels (Furring Members): 16 inches o.c.
- B. Isolate suspension systems from building structure where they abut or are penetrated by building structure to prevent transfer of loading imposed by structural movement.
- C. Suspend hangers from building structure as follows:
1. Install hangers plumb and free from contact with insulation or other objects within ceiling plenum that are not part of supporting structural or suspension system.
  2. Where width of ducts and other construction within ceiling plenum produces hanger spacings that interfere with locations of hangers required to support standard suspension system members, install supplemental suspension members and hangers in the form of trapezes or equivalent devices.
    - a. Size supplemental suspension members and hangers to support ceiling loads within performance limits established by referenced installation standards.
  3. Do not attach hangers to steel roof deck.
  4. Do not attach hangers to permanent metal forms. Furnish cast-in-place hanger inserts that extend through forms.
  5. Do not attach hangers to rolled-in hanger tabs of composite steel floor deck.
  6. Do not connect or suspend steel framing from ducts, pipes, or conduit.
- D. Seismic Bracing: Sway-brace suspension systems with hangers used for support.
- E. Installation Tolerances: Install suspension systems that are level to within 1/8 inch in 12 feet measured lengthwise on each member that will receive finishes and transversely between parallel members that will receive finishes.

END OF SECTION 092216

## SECTION 092900 - GYPSUM BOARD

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:

- 1. Interior gypsum board.

- B. Related Requirements:

- 1. Section 092216 "Non-Structural Metal Framing" for non-structural framing and suspension systems that support gypsum board panels.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.

#### 1.4 DELIVERY, STORAGE AND HANDLING

- A. Store materials inside under cover and keep them dry and protected against weather, condensation, direct sunlight, construction traffic, and other potential causes of damage. Stack panels flat and supported on risers on a flat platform to prevent sagging.

#### 1.5 FIELD CONDITIONS

- A. Environmental Limitations: Comply with ASTM C 840 requirements or gypsum board manufacturer's written recommendations, whichever are more stringent.

- B. Do not install paper-faced gypsum panels until installation areas are enclosed and conditioned.

- C. Do not install panels that are wet, those that are moisture damaged, and those that are mold damaged.

- 1. Indications that panels are wet or moisture damaged include, but are not limited to, discoloration, sagging, or irregular shape.

2. Indications that panels are mold damaged include, but are not limited to, fuzzy or splotchy surface contamination and discoloration.

## PART 2 - PRODUCTS

### 2.1 PERFORMANCE REQUIREMENTS

- A. STC-Rated Assemblies: For STC-rated assemblies, provide materials and construction identical to those tested in assembly indicated according to ASTM E 90 and classified according to ASTM E 413 by an independent testing agency.

### 2.2 GYPSUM BOARD, GENERAL

- A. Size: Provide maximum lengths and widths available that will minimize joints in each area and that correspond with support system indicated.

### 2.3 INTERIOR GYPSUM BOARD

- A. Gypsum Board, Type X: ASTM C 1396/C 1396M.

1. Thickness: 5/8 inch .
2. Long Edges: Tapered.

- B. Gypsum Ceiling Board: ASTM C1396/C1396M.

1. Thickness: 5/8 inch , Type X.
2. Long Edges: Tapered.

### 2.4 TRIM ACCESSORIES

- A. Interior Trim: ASTM C 1047.

1. Material: Galvanized or aluminum-coated steel sheet, rolled zinc, plastic, or paper-faced galvanized steel sheet.
2. Shapes:
  - a. Cornerbead.
  - b. LC-Bead: J-shaped; exposed long flange receives joint compound.

- B. Aluminum Trim: Extruded accessories of profiles and dimensions indicated.

1. Aluminum: Alloy and temper with not less than the strength and durability properties of ASTM B 221 , Alloy 6063-T5.
2. Finish: Corrosion-resistant primer compatible with joint compound and finish materials specified.

## 2.5 JOINT TREATMENT MATERIALS

- A. General: Comply with ASTM C 475/C 475M.
- B. Joint Tape:
  - 1. Interior Gypsum Board: Reinforced Fiberglass Tape
- C. Joint Compound for Interior Gypsum Board: For each coat use formulation that is compatible with other compounds applied on previous or for successive coats.
  - 1. Prefilling: At open joints, rounded or beveled panel edges, and damaged surface areas, use setting-type taping compound.
  - 2. Embedding and First Coat: For embedding tape and first coat on joints, fasteners, and trim flanges, use drying-type, all-purpose compound.
    - a. Use setting-type compound for installing paper-faced metal trim accessories.
  - 3. Fill Coat: For second coat, use drying-type, all-purpose compound.
  - 4. Finish Coat: For third coat, use drying-type, all-purpose compound.

## 2.6 AUXILIARY MATERIALS

- A. General: Provide auxiliary materials that comply with referenced installation standards and manufacturer's written recommendations.
- B. Steel Drill Screws: ASTM C 1002, unless otherwise indicated.
  - 1. Use screws complying with ASTM C 954 for fastening panels to steel members from 0.033 to 0.112 inch thick.
  - 2. For fastening cementitious backer units, use screws of type and size recommended by panel manufacturer.
- C. Sound-Attenuation Blankets: ASTM C665, Type I (blankets without membrane facing) produced by combining thermosetting resins with mineral fibers manufactured from glass, slag wool, or rock wool.
- D. Acoustical Joint Sealant: Manufacturer's standard nonsag, paintable, nonstaining latex sealant complying with ASTM C 834. Product effectively reduces airborne sound transmission through perimeter joints and openings in building construction as demonstrated by testing representative assemblies according to ASTM E 90.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine areas and substrates including welded hollow-metal frames and framing, with Installer present, for compliance with requirements and other conditions affecting performance.



- B. Examine panels before installation. Reject panels that are wet, moisture damaged, and mold damaged.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 APPLYING AND FINISHING PANELS, GENERAL

- A. Comply with ASTM C 840.
- B. Install ceiling panels across framing to minimize the number of abutting end joints and to avoid abutting end joints in central area of each ceiling. Stagger abutting end joints of adjacent panels not less than one framing member.
- C. Install panels with face side out. Butt panels together for a light contact at edges and ends with not more than 1/16 inch of open space between panels. Do not force into place.
- D. Locate edge and end joints over supports, except in ceiling applications where intermediate supports or gypsum board back-blocking is provided behind end joints. Do not place tapered edges against cut edges or ends. Stagger vertical joints on opposite sides of partitions. Do not make joints other than control joints at corners of framed openings.
- E. Form control and expansion joints with space between edges of adjoining gypsum panels.
- F. Cover both faces of support framing with gypsum panels in concealed spaces (above ceilings, etc.), except in chases braced internally.
  - 1. Unless concealed application is indicated or required for sound, fire, air, or smoke ratings, coverage may be accomplished with scraps of not less than 8 sq. ft. in area.
  - 2. Fit gypsum panels around ducts, pipes, and conduits.
  - 3. Where partitions intersect structural members projecting below underside of floor/roof slabs and decks, cut gypsum panels to fit profile formed by structural members; allow 1/4- to 3/8-inch-wide joints to install sealant.
- G. Isolate perimeter of gypsum board applied to non-load-bearing partitions at structural abutments, except floors. Provide 1/4- to 1/2-inch-wide spaces at these locations and trim edges with edge trim where edges of panels are exposed. Seal joints between edges and abutting structural surfaces with acoustical sealant.
- H. Attachment to Steel Framing: Attach panels so leading edge or end of each panel is attached to open (unsupported) edges of stud flanges first.
- I. STC-Rated Assemblies: Seal construction at perimeters, behind control joints, and at openings and penetrations with a continuous bead of acoustical sealant. Install acoustical sealant at both faces of partitions at perimeters and through penetrations. Comply with ASTM C919 and with manufacturer's written instructions for locating edge trim and closing off sound-flanking paths around or through assemblies, including sealing partitions above acoustical ceilings.
- J. Install sound attenuation blankets before installing gypsum panels unless blankets are readily installed after panels have been installed on one side.

### 3.3 APPLYING INTERIOR GYPSUM BOARD

- A. Install interior gypsum board in the following locations:
1. Wallboard Type: Vertical surfaces unless otherwise indicated.
  2. Ceiling Type: Ceiling surfaces.
  3. Type X: Vertical surfaces unless otherwise indicated.
- B. Single-Layer Application:
1. On ceilings, apply gypsum panels before wall/partition board application to greatest extent possible and at right angles to framing unless otherwise indicated.
  2. On partitions/walls, apply gypsum panels horizontally (perpendicular to framing) unless otherwise indicated or required by fire-resistance-rated assembly, and minimize end joints.
    - a. Stagger abutting end joints not less than one framing member in alternate courses of panels.
    - b. At stairwells and other high walls, install panels horizontally unless otherwise indicated or required by fire-resistance-rated assembly.
  3. On Z-furring members, apply gypsum panels vertically (parallel to framing) with no end joints. Locate edge joints over furring members.
  4. Fastening Methods: Apply gypsum panels to supports with steel drill screws.

### 3.4 INSTALLING TRIM ACCESSORIES

- A. General: For trim with back flanges intended for fasteners, attach to framing with same fasteners used for panels. Otherwise, attach trim according to manufacturer's written instructions.
- B. Control Joints: Install control joints according to ASTM C 840 and in specific locations approved by Government for visual effect.
- C. Interior Trim: Install in the following locations:
1. Cornerbead: Use at outside corners.
  2. LC-Bead: Use at exposed panel edges.
- D. Aluminum Trim: Install in locations indicated on Drawings.

### 3.5 FINISHING GYPSUM BOARD

- A. General: Treat gypsum board joints, interior angles, edge trim, control joints, penetrations, fastener heads, surface defects, and elsewhere as required to prepare gypsum board surfaces for decoration. Promptly remove residual joint compound from adjacent surfaces.

- B. Prefill open joints, rounded or beveled edges, and damaged surface areas.
- C. Apply joint tape over gypsum board joints, except for trim products specifically indicated as not intended to receive tape.
- D. Gypsum Board Finish Levels: Finish panels to levels indicated below and according to ASTM C 840:
  - 1. Level 4: At panel surfaces that will be exposed to view unless otherwise indicated.
    - a. Primer and its application to surfaces are specified in Section 099123 "Interior Painting."

### 3.6 PROTECTION

- A. Protect adjacent surfaces from drywall compound and promptly remove from floors and other non-drywall surfaces. Repair surfaces stained, marred, or otherwise damaged during drywall application.
- B. Protect installed products from damage from weather, condensation, direct sunlight, construction, and other causes during remainder of the construction period.
- C. Remove and replace panels that are wet, moisture damaged, and mold damaged.
  - 1. Indications that panels are wet or moisture damaged include, but are not limited to, discoloration, sagging, or irregular shape.
  - 2. Indications that panels are mold damaged include, but are not limited to, fuzzy or splotchy surface contamination and discoloration.

END OF SECTION 092900

## SECTION 093000 – PORCELAIN TILE

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:

- 1. Ceramic tile.
- 1. Uncoupling and water proofing membrane for thin-set tile installations.
- 2. Movement joint profile.
- 3. Metal edge strips installed as part of tile installations.

- B. Related Sections:

- 1. Division 07 Section "Joint Sealants" for sealing of expansion, contraction, control, and isolation joints in tile surfaces.
- 2. Division 09 Section "Gypsum Board" for tile backing panels.

#### 1.3 DEFINITIONS

- A. General: Definitions in the ANSI A108 series of tile installation standards and in ANSI A137.1 apply to Work of this Section unless otherwise specified.
- B. ANSI A108 Series: ANSI A108.01, ANSI A108.02, ANSI A108.1A, ANSI A108.1B, ANSI A108.1C, ANSI A108.4, ANSI A108.5, ANSI A108.6, ANSI A108.8, ANSI A108.9, ANSI A108.10, ANSI A108.11, ANSI A108.12, ANSI A108.13, ANSI A108.14, ANSI A108.15, ANSI A108.16, and ANSI A108.17, which are contained in "American National Standard Specifications for Installation of Ceramic Tile."
- C. Module Size: Actual tile size plus joint width indicated.
- D. Face Size: Actual tile size, excluding spacer lugs.

#### 1.4 PERFORMANCE REQUIREMENTS

- A. Static Coefficient of Friction: For tile installed on walkway surfaces, provide products with the following values as determined by testing identical products per ASTM C 1028:

1. Level Surfaces: Minimum 0.60 C.O.F. Wet, 0.70 C.O.F. Dry.

#### 1.5 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: Show locations of each type of tile and tile pattern. Show widths, details, and locations of expansion, contraction, control, and isolation joints in tile substrates and finished tile surfaces.
- C. Samples for Initial Selection: For each type of tile and grout indicated. Include Samples of accessories involving color selection.
- D. Samples for Verification:
  1. Full-size units of each type and composition of tile and for each color and finish required.
  2. Full-size units of each type of trim and accessory for each color and finish required.
  3. Stone thresholds in 6-inch (150-mm) lengths.
  4. Metal edge strips in 6-inch (150-mm) lengths.

#### 1.6 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For qualified Installer.

#### 1.7 MATERIALS MAINTENANCE SUBMITTALS

- A. Furnish extra materials that match and are from same production runs as products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  1. Tile and Trim Units: Furnish quantity of full-size units equal to 3 percent of amount installed for each type, composition, color, pattern, and size indicated.
  2. Grout: Furnish quantity of grout equal to 3 percent of amount installed for each type, composition, and color indicated.

#### 1.8 QUALITY ASSURANCE

- A. Source Limitations for Tile: Obtain tile of each type and color or finish from one source or producer.
  1. Obtain tile of each type and color or finish from same production run and of consistent quality in appearance and physical properties for each contiguous area.
- B. Source Limitations for Setting and Grouting Materials: Obtain ingredients of a uniform quality for each mortar, adhesive, and grout component from one manufacturer and each aggregate from one source or producer.

- C. Source Limitations for Other Products: Obtain each of the following products specified in this Section from a single manufacturer for each product:
  - 1. Joint sealants.
  - 2. Cementitious backer units.

#### 1.9 DELIVERY, STORAGE, AND HANDLING

- A. Deliver and store packaged materials in original containers with seals unbroken and labels intact until time of use. Comply with requirements in ANSI A137.1 for labeling tile packages.
- B. Store tile and cementitious materials on elevated platforms, under cover, and in a dry location.
- C. Store aggregates where grading and other required characteristics can be maintained and contamination can be avoided.
- D. Store liquid materials in unopened containers and protected from freezing.
- E. Handle tile that has temporary protective coating on exposed surfaces to prevent coated surfaces from contacting backs or edges of other units. If coating does contact bonding surfaces of tile, remove coating from bonding surfaces before setting tile.

#### 1.10 PROJECT CONDITIONS

- A. Environmental Limitations: Do not install tile until construction in spaces is complete and ambient temperature and humidity conditions are maintained at the levels indicated in referenced standards and manufacturer's written instructions.

### PART 2 - PRODUCTS

#### 2.1 PRODUCTS, GENERAL

- A. ANSI Ceramic Tile Standard: Provide tile that complies with ANSI A137.1 for types, compositions, and other characteristics indicated.
  - 1. Provide tile complying with Standard grade requirements unless otherwise indicated.
- B. ANSI Standards for Tile Installation Materials: Provide materials complying with ANSI A108.02, ANSI standards referenced in other Part 2 articles, ANSI standards referenced by TCA installation methods specified in tile installation schedules, and other requirements specified.
- C. Factory Blending: For tile exhibiting color variations within ranges, blend tile in factory and package so tile units taken from one package show same range in colors as those taken from other packages and match approved Samples.

- D. Factory-Applied Temporary Protective Coating: Where indicated under tile type, protect exposed surfaces of tile against adherence of mortar and grout by precoating with continuous film of petroleum paraffin wax, applied hot. Do not coat unexposed tile surfaces.

2.2 TILE PRODUCTS - See Finish Schedule and legend for Specified Products.

2.3 THRESHOLDS

- A. General: Fabricate to sizes and profiles indicated or required to provide transition between adjacent floor finishes.
  - 1. Bevel edges at 1:2 slope, with lower edge of bevel aligned with or up to 1/16 inch above adjacent floor surface. Finish bevel to match top surface of threshold. Limit height of threshold to 1/2 inch or less above adjacent floor surface.
- B. Metal Edge Strips: Angle, height to match tile and setting-bed thickness, metallic or combination of metal and PVC or neoprene base, designed specifically for flooring applications, stainless steel; ASTM A 666, 300 Series exposed-edge material.
  - 1. Basis of Design: Schluter Reno TK (tile to carpet)
  - 2. Or approved equal.

2.4 UNCOUPLING MEMBRANE SYSTEM

- A. Uncoupling membrane: 1/8" (3 mm) thick, orange, high-density polyethylene membrane with a grid structure of 1/2" x 1/2" (12 mm x 12 mm) square cavities, each cut back in a dovetail configuration, and a polypropylene anchoring fleece laminated to its underside.
  - 1. Basis of Design: Schluter Ditra
  - 2. Or approved equal

2.5 SETTING MATERIALS

- A. Latex-Portland Cement Mortar (Thin Set): ANSI A118.4. **(Walls & Floors)**
  - 1. Basis-of-Design Product: Subject to compliance with requirements, provide Laticrete International, Inc #253 Gold or comparable approved equal product by one of the following:
    - a. Bonsal American; an Oldcastle company.
    - b. Custom Building Products.
  - 2. Provide prepackaged, dry-mortar mix containing dry, redispersible, vinyl acetate or acrylic additive to which only water must be added at Project site.
  - 3. Provide prepackaged, dry-mortar mix combined with liquid-latex additive at Project site.

4. For wall applications, provide mortar that complies with requirements for nonsagging mortar in addition to the other requirements in ANSI A118.4.

## 2.6 GROUT MATERIALS

### A. Epoxy Grout: ANSI A118.3. **(Walls & Floors)**

1. Basis-of-Design Product: Subject to compliance with requirements, provide Laticrete International, Inc SpectraLOCK Pro Premium Grout or comparable approved equal product by one of the following:
  - a. Bonsal American; an Oldcastle company.
  - b. Custom Building Products.

## 2.7 ELASTOMERIC SEALANTS

- A. General: Provide sealants, primers, backer rods, and other sealant accessories that comply with the following requirements and with the applicable requirements in Division 07 Section "Joint Sealants."
  1. Use primers, backer rods, and sealant accessories recommended by sealant manufacturer.
- B. Colors: Provide colors of exposed sealants to match colors of grout in tile adjoining sealed joints unless otherwise indicated.
- C. One-Part, Mildew-Resistant Silicone Sealant: ASTM C 920; Type S; Grade NS; Class 25; Uses NT, G, A, and, as applicable to nonporous joint substrates indicated, O; formulated with fungicide, intended for sealing interior ceramic tile joints and other nonporous substrates that are subject to in-service exposures of high humidity and extreme temperatures.
- D. Multipart, Pourable Urethane Sealant for Use T: ASTM C 920; Type M; Grade P; Class 25; Uses T, M, A, and, as applicable to joint substrates indicated, O.
- E. Chemical-Resistant Sealants: For chemical-resistant floors, provide chemical-resistant elastomeric sealant of type recommended and produced by chemical-resistant mortar and grout manufacturer for type of application indicated, with proven service record and compatibility with tile and other setting materials, and with chemical resistance equivalent to mortar/grout.

## 2.8 MISCELLANEOUS MATERIALS

- A. Trowelable Underlayments and Patching Compounds: Latex-modified, portland cement-based formulation provided or approved by manufacturer of tile-setting materials for installations indicated.
- B. Temporary Protective Coating: Either product indicated below that is formulated to protect exposed surfaces of tile against adherence of mortar and grout; compatible with tile, mortar, and grout products; and easily removable after grouting is completed without damaging grout or tile.



1. Petroleum paraffin wax, fully refined and odorless, containing at least 0.5 percent oil with a melting point of 120 to 140 deg F per ASTM D 87.
  2. Grout release in form of manufacturer's standard proprietary liquid coating that is specially formulated and recommended for use as temporary protective coating for tile.
- C. Tile Cleaner: A neutral cleaner capable of removing soil and residue without harming tile and grout surfaces, specifically approved for materials and installations indicated by tile and grout manufacturers.

## 2.9 MIXING MORTARS AND GROUT

- A. Mix mortars and grouts to comply with referenced standards and mortar and grout manufacturers' written instructions.
- B. Add materials, water, and additives in accurate proportions.
- C. Obtain and use type of mixing equipment, mixer speeds, mixing containers, mixing time, and other procedures to produce mortars and grouts of uniform quality with optimum performance characteristics for installations indicated.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions where tile will be installed, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of installed tile.
  1. Verify that substrates for setting tile are firm, dry, clean, and free of coatings that are incompatible with tile-setting materials including curing compounds and other substances that contain soap, wax, oil, or silicone; and comply with flatness tolerances required by ANSI A108.01 for installations indicated.
  2. Verify that installation of grounds, anchors, recessed frames, electrical and mechanical units of work, and similar items located in or behind tile has been completed.
  3. Verify that joints and cracks in tile substrates are coordinated with tile joint locations; if not coordinated, adjust joint locations in consultation with Architect.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Fill cracks, holes, and depressions in concrete substrates for tile floors installed with adhesives or thin-set mortar with trowelable leveling and patching compound specifically recommended by tile-setting material manufacturer.

- B. Where indicated, prepare substrates to receive waterproofing by applying a reinforced mortar bed that complies with ANSI A108.1A and is sloped 1/4 inch per foot toward drains.
- C. Blending: For tile exhibiting color variations, verify that tile has been factory blended and packaged so tile units taken from one package show same range of colors as those taken from other packages and match approved Samples. If not factory blended, either return to manufacturer or blend tiles at Project site before installing.
- D. Field-Applied Temporary Protective Coating: If indicated under tile type or needed to prevent grout from staining or adhering to exposed tile surfaces, precoat them with continuous film of temporary protective coating, taking care not to coat unexposed tile surfaces.

### 3.3 TILE INSTALLATION

- A. Comply with TCA's "Handbook for Ceramic Tile Installation" for TCA installation methods specified in tile installation schedules. Comply with parts of the ANSI A108.1b Series "Specifications for Installation of Ceramic Tile" that are referenced in TCA installation methods, specified in tile installation schedules, and apply to types of setting and grouting materials used.
  - 1. For the following installations, Obtain (100%) hundred percent mortar coverage with no voids by no back buttering:
    - a. Tile floors in wet areas.
    - b. Tile floors composed of tiles 8 by 8 inches or larger.
    - c. Tile floors composed of rib-backed tiles.
  - B. Extend tile work into recesses and under or behind equipment and fixtures to form complete covering without interruptions unless otherwise indicated. Terminate work neatly at obstructions, edges, and corners without disrupting pattern or joint alignments.
  - C. Accurately form intersections and returns. Perform cutting and drilling of tile without marring visible surfaces. Carefully grind cut edges of tile abutting trim, finish, or built-in items for straight aligned joints. Fit tile closely to electrical outlets, piping, fixtures, and other penetrations so plates, collars, or covers overlap tile.
  - D. Jointing Pattern: Lay tile in grid pattern unless otherwise indicated. Lay out tile work and center tile fields in both directions in each space or on each wall area. Lay out tile work to minimize the use of pieces that are less than half of a tile. Provide uniform joint widths unless otherwise indicated.
    - 1. Where adjoining tiles on floor, base, walls, or trim are specified or indicated to be same size, align joints.
    - 2. Where tiles are specified or indicated to be whole integer multiples of adjoining tiles on floor, base, walls, or trim, align joints unless otherwise indicated.
  - E. Joint Widths: Unless otherwise indicated, install tile with the following joint widths:
    - 1. Porcelain Tile: 1/16 inch.

- F. Lay out tile wainscots to dimensions indicated or to next full tile beyond dimensions indicated.
- G. Expansion Joints: Provide expansion joints and other sealant-filled joints, including control, contraction, and isolation joints, where indicated. Form joints during installation of setting materials, mortar beds, and tile. Do not saw-cut joints after installing tiles.
  - 1. Where joints occur in concrete substrates, locate joints in tile surfaces directly above them.
  - 2. Prepare joints and apply sealants to comply with requirements in Division 07 Section "Joint Sealants."
- H. Stone Thresholds: Install stone thresholds in same type of setting bed as adjacent floor unless otherwise indicated.

### 3.4 CLEANING AND PROTECTING

- A. Cleaning: On completion of placement and grouting, clean all ceramic tile surfaces so they are free of foreign matter.
  - 1. Remove epoxy and latex-portland cement grout residue from tile as soon as possible.
  - 2. Clean grout smears and hazes from tile according to tile and grout manufacturer's written instructions but no sooner than 10 days after installation. Use only cleaners recommended by tile and grout manufacturers and only after determining that cleaners are safe to use by testing on samples of tile and other surfaces to be cleaned. Protect metal surfaces and plumbing fixtures from effects of cleaning. Flush surfaces with clean water before and after cleaning.
  - 3. Remove temporary protective coating by method recommended by coating manufacturer and that is acceptable to tile and grout manufacturer. Trap and remove coating to prevent drain clogging.
- B. Protect installed tile work with kraft paper or other heavy covering during construction period to prevent staining, damage, and wear. If recommended by tile manufacturer, apply coat of neutral protective cleaner to completed tile walls and floors.
- C. Prohibit foot and wheel traffic from tiled floors for at least seven days after grouting is completed.
- D. Before final inspection, remove protective coverings and rinse neutral protective cleaner from tile surfaces.

### 3.5 INTERIOR TILE INSTALLATION SCHEDULE

- A. Interior Floor Installations, Concrete Subfloor :
  - 1. Tile Installation F128-14: Cement Mortar with Epoxy Grout.
    - a. Tile Type: PT-1
    - b. Mortar Bed: Cement mortar.

- c. Uncoupling membrane.
- d. Grout: Epoxy grout.

B. Interior Wall Installations, Metal Studs or Furring:

1. Tile Installation W243: Thin-set mortar on gypsum board; TCA W244C.

- a. Tile Type: PWT-1 & PWT-2
- b. Thin-Set Mortar: Latex-Portland cement mortar.
- c. Grout: Epoxy grout.

C. Movement Joint Installations, Perimeter Joint: EJ171I-11, using Schluter®-DILEX-BWA or approved equal.

END OF SECTION 093000

## SECTION 095123 - ACOUSTICAL TILE CEILINGS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Acoustical tiles for ceilings.
  - 2. Concealed suspension systems.
- B. Products furnished, but not installed under this Section, include anchors, clips, and other ceiling attachment devices to be cast in concrete.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Construction Waste Management shall be managed by the General Contractor in accordance with the provisions of Section 017419 – Construction Waste Management and Disposal. Documentation shall be submitted to satisfy the requirements of that section.
- C. Samples: For each exposed product and for each color and texture specified, 6-inches-in size.

#### 1.4 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Reflected ceiling plans, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of the items involved:
  - 1. Ceiling suspension-system members.
  - 2. Method of attaching hangers to building structure.
    - a. Furnish layouts for cast-in-place anchors, clips, and other ceiling attachment devices whose installation is specified in other Sections.
  - 3. Size and location of initial access modules for acoustical tile.
  - 4. Ceiling-mounted items including lighting fixtures, diffusers, grilles, speakers, sprinklers, access panels, and special moldings.
  - 5. Minimum Drawing Scale: 1/8 inch = 1 foot.

6. Provide ESR reports for seismic ceiling installation.

#### 1.5 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For finishes to include in maintenance manuals.

#### 1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  1. Acoustical Ceiling Units: Full-size tiles equal to 2 percent of quantity installed.
  2. Suspension-System Components: Quantity of each concealed grid and exposed component equal to 2 percent of quantity installed.

#### 1.7 QUALITY ASSURANCE

- A. Testing Agency Qualifications: Qualified according to the National Voluntary Laboratory Accreditation Program (NVLAP) for testing indicated.

#### 1.8 DELIVERY, STORAGE, AND HANDLING

- A. Deliver acoustical tiles, suspension-system components, and accessories to Project site in original, unopened packages and store them in a fully enclosed, conditioned space where they will be protected against damage from moisture, humidity, temperature extremes, direct sunlight, surface contamination, and other causes.
- B. Before installing acoustical tiles, permit them to reach room temperature and a stabilized moisture content.
- C. Handle acoustical tiles carefully to avoid chipping edges or damaging units in any way.

#### 1.9 FIELD CONDITIONS

- A. Environmental Limitations: Do not install acoustical tile ceilings until spaces are enclosed and weatherproof, wet work in spaces is complete and dry, work above ceilings is complete, and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.
  1. Pressurized Plenums: Operate ventilation system for not less than 48 hours before beginning acoustical tile ceiling installation.

## PART 2 - PRODUCTS

### 2.1 PERFORMANCE REQUIREMENTS

- A. Seismic Performance: Acoustical ceiling shall withstand the effects of earthquake motions determined according to ASCE/SEI 7 & CISCA Seismic Zones 3 & 4 – Ceilings and Interior Systems Construction Association Guidelines for Seismic Restraint for Direct Hung Suspended Ceiling Assemblies – Category “D”.
- B. Seismic Loads: Design and size components to withstand seismic loads in accordance with the International Building Code, Section 1621 for **Category D**.
- C. Surface-Burning Characteristics: Comply with ASTM E 84; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
  - 1. Flame-Spread Index: Comply with ASTM E 1264 for Class A materials.
  - 2. Smoke-Developed Index: 50 or less.

### 2.2 ACOUSTICAL TILES, GENERAL

- A. Source Limitations:
  - 1. Acoustical Ceiling Tile: Obtain each type from single source from single manufacturer.
  - 2. Suspension System: Obtain each type from single source from single manufacturer.
- B. Source Limitations: Obtain each type of acoustical ceiling tile and supporting suspension system from single source from single manufacturer.
- C. Recycled Content: Postconsumer recycled content plus one-half of preconsumer recycled content not less than 55% percent.
- D. Acoustical Tile Standard: Provide manufacturer's standard tiles of configuration indicated that comply with ASTM E 1264 classifications as designated by types, patterns, acoustical ratings, and light reflectances unless otherwise indicated.
  - 1. Mounting Method for Measuring NRC: Type E-400; plenum mounting in which face of test specimen is 15-3/4 inches away from test surface according to ASTM E 795.
- E. Acoustical Tile Colors and Patterns: Match appearance characteristics indicated for each product type.
  - 1. Where appearance characteristics of acoustical tiles are indicated by referencing pattern designations in ASTM E 1264 and not manufacturers' proprietary product designations, provide products selected by Architect from each manufacturer's full range that comply with requirements indicated for type, pattern, color, light reflectance, acoustical performance, edge detail, and size.

### 2.3 ACOUSTICAL TILES ACT-1

- A. Manufacturers: Ceiling tiles must match existing, provide the following:
  - 1. Basis of Design: USG, RADAR Basic Acoustical Tiles
- B. Classification: Provide tiles complying with ASTM E 1264 for type, form, and pattern as follows:
  - 1. Type and Form: Type IV, mineral base with painted finish; Form 2, water felted.
  - 2. Pattern: E.
- C. Color: White.
- D. LR: Not less than 0.87.
- E. NRC: Not less than 0.80.
- F. CAC: Not less than 35.
- G. Edge/Joint Detail: Square regular.
- H. Thickness: 7/8 inch.
- I. Modular Size: 24x24.
- J. Broad Spectrum Antimicrobial Fungicide and Bactericide Treatment: Provide acoustical tiles treated with manufacturer's standard antimicrobial formulation that inhibits fungus, mold, mildew, and gram-positive and gram-negative bacteria and showing no mold, mildew, or bacterial growth when tested according to ASTM D 3273 and evaluated according to ASTM D 3274 or ASTM G 21.

### 2.4 METAL SUSPENSION SYSTEMS, GENERAL ACT-1

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Armstrong World Industries, Inc., Prelude XL
  - 2. Or approved equal.
- B. Recycled Content: Postconsumer recycled content plus one-half of preconsumer recycled content not less than 55% percent.
- C. Metal Suspension-System Standard: Provide manufacturer's standard metal suspension systems of types, structural classifications, and finishes indicated that comply with applicable requirements in ASTM C 635/C 635M.
- D. Wire Hangers, Braces, and Ties: Provide wires complying with the following requirements:



1. Zinc-Coated, Carbon-Steel Wire: ASTM A 641/A 641M, Class 1 zinc coating, soft temper.
  2. Size: Select wire diameter so its stress at three times hanger design load (ASTM C 635/C 635M, Table 1, "Direct Hung") will be less than yield stress of wire but provide not less than 12-gauge wire.
- E. Hanger Rods or Flat Hangers: Mild steel, zinc coated or protected with rust-inhibitive paint.
- F. Angle Hangers: Angles with legs not less than 7/8-inch-wide; formed with 0.04-inch-thick, galvanized-steel sheet complying with ASTM A 653/A 653M, G90 coating designation; with bolted connections and 5/16-inch-diameter bolts.
- G. Seismic Struts: Manufacturer's standard compression struts designed to accommodate lateral forces.
- H. Seismic Clips: Manufacturer's standard seismic clips designed and spaced to secure acoustical tiles in-place.

## 2.5 METAL SUSPENSION SYSTEM

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- B. Direct-Hung, Double-Web Suspension System: Main and cross runners roll formed from and capped with cold-rolled steel sheet, prepainted, electrolytically zinc coated, or hot-dip galvanized according to ASTM A 653/A 653M, G30 coating designation.
1. Structural Classification: Heavy-duty system.
  2. Access: Upward and end pivoted, with initial access openings of size indicated below and located throughout ceiling within each module formed by main and cross runners, with additional access available by progressively removing remaining acoustical tiles.
    - a. Initial Access Opening: In each module, 24 by 24 inches.

## 2.6 METAL EDGE MOLDINGS AND TRIM

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
1. Armstrong World Industries, Inc., BERC2 Clip
  2. Or approved equal.
- B. Extruded-Aluminum Edge Moldings and Trim: Where indicated, provide manufacturer's extruded-aluminum edge shadow reveal transition molding at ACT to gypsum transition and perimeter shadow molding at all other instances. Trim of profile indicated or referenced by manufacturer's designations, including splice plates, corner pieces, and attachment and other clips and complying with seismic design requirements and the following:

1. Aluminum Alloy: Alloy and temper recommended by aluminum producer and finisher for type of use and finish indicated and with not less than the strength and durability properties of aluminum extrusions complying with ASTM B 221 for Alloy and Temper 6063-T5.
2. Baked-Enamel or Powder-Coat Finish: Minimum dry film thickness of 1.5 mils. Comply with ASTM C 635/C 635M and coating manufacturer's written instructions for cleaning, conversion coating, and applying and baking finish.

## 2.7 ACOUSTICAL SEALANT

- A. Acoustical Sealant: Manufacturer's standard sealant complying with ASTM C 834 and effective in reducing airborne sound transmission through perimeter joints and openings in building construction as demonstrated by testing representative assemblies according to ASTM E 90.
  1. Exposed and Concealed Joints: Nonsag, paintable, nonstaining latex sealant.
  2. Concealed Joints: Nondrying, nonhardening, nonskinning, nonstaining, gunnable, synthetic-rubber sealant.
  3. Acoustical sealant shall have a VOC content of 250 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

## 2.8 MISCELLANEOUS MATERIALS

- A. Acoustical Tile Adhesive: Type recommended by acoustical tile manufacturer, bearing UL label for Class 0-25 flame spread.
  1. Adhesive shall have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- B. Staples: 5/16-inch-long, divergent-point staples.
- C. Oversized Seismic Sprinkler Trim Ring: If hard pipe to sprinkler heads are used then GC to provide oversized trim rings at each sprinkler head. Cut acoustical ceiling tile to provide 1" gap around fixed pipe. Oversized trim ring to conceal gap.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, including structural framing and substrates to which acoustical tile ceilings attach or abut, with Installer present, for compliance with requirements specified in this and other Sections that affect ceiling installation and anchorage and for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.

- B. Examine acoustical tiles before installation. Reject acoustical tiles that are wet, moisture damaged, or mold damaged.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Testing Substrates: Before installing adhesively applied tiles on wet-placed substrates such as cast-in-place concrete or plaster, test and verify that moisture level is below tile manufacturer's recommended limits.
- B. Measure each ceiling area and establish layout of acoustical tiles to balance border widths at opposite edges of each ceiling. Avoid using less-than-half-width tiles at borders and comply with layout shown on reflected ceiling plans.

### 3.3 INSTALLATION OF SUSPENDED ACOUSTICAL TILE CEILINGS

- A. General: Install acoustical panel ceilings to comply with ASTM C 636/C 636M and seismic design requirements indicated, according to manufacturer's written instructions and CISCA's "Ceiling Systems Handbook." Install according to ESR report.
- B. Suspend ceiling hangers from building's structural members and as follows:
  - 1. Install hangers plumb and free from contact with insulation or other objects within ceiling plenum that are not part of supporting structure or of ceiling suspension system.
  - 2. Splay hangers only where required to miss obstructions; offset resulting horizontal forces by bracing, countersplaying, or other equally effective means.
  - 3. Where width of ducts and other construction within ceiling plenum produces hanger spacings that interfere with location of hangers at spacings required to support standard suspension-system members, install supplemental suspension members and hangers in form of trapezes or equivalent devices.
  - 4. Secure wire hangers to ceiling suspension members and to supports above with a minimum of three tight turns. Connect hangers directly either to structures or to inserts, eye screws, or other devices that are secure and appropriate for substrate and that will not deteriorate or otherwise fail due to age, corrosion, or elevated temperatures.
  - 5. Secure flat, angle, channel, and rod hangers to structure, including intermediate framing members, by attaching to inserts, eye screws, or other devices that are secure and appropriate for both the structure to which hangers are attached and the type of hanger involved. Install hangers in a manner that will not cause them to deteriorate or fail due to age, corrosion, or elevated temperatures.
  - 6. Do not support ceilings directly from permanent metal forms or floor deck. Fasten hangers to cast-in-place hanger inserts, post installed mechanical or adhesive anchors, or power-actuated fasteners that extend through forms into concrete.
  - 7. When steel framing does not permit installation of hanger wires at spacing required, install carrying channels or other supplemental support for attachment of hanger wires.
  - 8. Do not attach hangers to steel deck tabs.
  - 9. Do not attach hangers to steel roof deck. Attach hangers to structural members.

10. Space hangers not more than 48 inches o.c. along each member supported directly from hangers unless otherwise indicated; provide hangers not more than 8 inches from ends of each member.
  11. Size supplemental suspension members and hangers to support ceiling loads within performance limits established by referenced standards and publications.
- C. Secure bracing wires to ceiling suspension members and to supports with a minimum of four tight turns. Suspend bracing from building's structural members as required for hangers without attaching to permanent metal forms, steel deck, or steel deck tabs. Fasten bracing wires into concrete with cast-in-place or postinstalled anchors.
- D. Install edge moldings and trim of type indicated at perimeter of acoustical tile ceiling area and where necessary to conceal edges of acoustical tiles.
1. Apply acoustical sealant in a continuous ribbon concealed on back of vertical legs of moldings before they are installed.
  2. Screw attach moldings to substrate at intervals not more than 16 inches o.c. and not more than 3 inches from ends, leveling with ceiling suspension system to a tolerance of 1/8 inch in 12 feet . Miter corners accurately and connect securely.
  3. Do not use exposed fasteners, including pop rivets, on moldings and trim.
- E. Install suspension-system runners so they are square and securely interlocked with one another. Remove and replace dented, bent, or kinked members.
- F. Arrange directionally patterned acoustical tiles as follows:
1. Install tiles with pattern running in one direction parallel to long axis of space.
- G. Install acoustical tiles in coordination with suspension system and exposed moldings and trim. Place splines or suspension-system flanges into kerfed edges so tile-to-tile joints are closed by double lap of material.
1. Fit adjoining tile to form flush, tight joints. Scribe and cut tile for accurate fit at borders and around penetrations through tile.
  2. Hold tile field in compression by inserting leaf-type, spring-steel spacers between tile and moldings, spaced 12 inches o.c.
  3. Protect lighting fixtures and air ducts to comply with requirements indicated for fire-resistance-rated assembly.

### 3.4 CLEANING

- A. Clean exposed surfaces of acoustical tile ceilings, including trim and edge moldings. Comply with manufacturer's written instructions for cleaning and touchup of minor finish damage. Remove and replace tiles and other ceiling components that cannot be successfully cleaned and repaired to permanently eliminate evidence of damage.

END OF SECTION 095123

## SECTION 096513 - RESILIENT BASE AND ACCESSORIES

### PART 1 - GENERAL

#### 1.3 RELATED DOCUMENTS

- B. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.4 SUMMARY

- B. Section Includes:
  - 1. Resilient base.
  - 2. Resilient molding accessories.

#### 1.5 ACTION SUBMITTALS

- B. Product Data: For each type of product.
- C. Samples: For each exposed product and for each color and texture specified, not less than 12 inches long.

#### 1.6 MAINTENANCE MATERIAL SUBMITTALS

- B. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Furnish not less than 10 linear feet for every 500 linear feet or fraction thereof, of each type, color, pattern, and size of resilient product installed.

#### 1.7 QUALITY ASSURANCE

- B. Mockups: Build mockups to verify selections made under Sample submittals and to demonstrate aesthetic effects and set quality standards for materials and execution.
  - 1. Coordinate mockups in this Section with mockups specified in other Sections.

1.8 DELIVERY, STORAGE, AND HANDLING

- B. Store resilient products and installation materials in dry spaces protected from the weather, with ambient temperatures maintained within range recommended by manufacturer, but not less than 50 deg F or more than 90 deg F.

1.9 FIELD CONDITIONS

- B. Maintain ambient temperatures within range recommended by manufacturer, but not less than 64 deg F or more than 85 deg F, in spaces to receive resilient products during the following time periods:
  - 1. 48 hours before installation.
  - 2. During installation.
  - 3. 48 hours after installation.
- C. After installation and until Substantial Completion, maintain ambient temperatures within range recommended by manufacturer, but not less than 55 deg F or more than 85 deg F.
- D. Install resilient products after other finishing operations, including painting, have been completed.

PART 2 - PRODUCTS

2.3 THERMOSET-RUBBER BASE RB-1

- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Basis of Design: Johnsonite.
  - 2. Mannington
  - 3. Roppe
  - 4. Or approved equal.
- C. Product Standard: ASTM F 1861, Type TS (rubber, thermoset), Group I (solid, homogeneous).
  - 1. Style and Location:
    - a. Cove.
- D. Thickness: 1/8" inch.
- E. Height: 4 inches.
- F. Lengths: Coils in manufacturer's standard length.
- G. Outside Corners: Job formed.

- H. Inside Corners: Job formed.

#### 2.4 RESILIENT MOLDING ACCESSORIES

- B. **Manufacturers:** Subject to compliance with requirements, provide products by one of the following:
  - 1. Johnsonite.
  - 2. Mannington
  - 3. Roppe
  - 4. Or approved equal.
- C. Description: Rubber transition strips.
- D. Profile and Dimensions: As indicated.
- E. Locations: Provide rubber molding accessories at flooring finish transition.
- F. Colors and Patterns: As selected by Architect on sheet I-601 Finish Legend.

#### 2.5 INSTALLATION MATERIALS

- B. Trowelable Leveling and Patching Compounds: Latex-modified, portland cement based or blended hydraulic-cement-based formulation provided or approved by resilient-product manufacturer for applications indicated.
- C. Adhesives: Water-resistant type recommended by resilient-product manufacturer for resilient products and substrate conditions indicated.
  - 1. Adhesives shall have a VOC content of 50 g/L or less.

### PART 3 - EXECUTION

#### 3.3 EXAMINATION

- B. Examine substrates, with Installer present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the Work.
  - 1. Verify that finishes of substrates comply with tolerances and other requirements specified in other Sections and that substrates are free of cracks, ridges, depressions, scale, and foreign deposits that might interfere with adhesion of resilient products.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.
  - 1. Installation of resilient products indicates acceptance of surfaces and conditions.

### 3.4 PREPARATION

- B. Prepare substrates according to manufacturer's written instructions to ensure adhesion of resilient products.
- C. Fill cracks, holes, and depressions in substrates with trowelable leveling and patching compound; remove bumps and ridges to produce a uniform and smooth substrate.
- D. Do not install resilient products until they are the same temperature as the space where they are to be installed.
  - 1. At least 48 hours in advance of installation, move resilient products and installation materials into spaces where they will be installed.
- E. Immediately before installation, sweep and vacuum clean substrates to be covered by resilient products.

### 3.5 RESILIENT BASE INSTALLATION

- B. Comply with manufacturer's written instructions for installing resilient base.
- C. Apply resilient base to walls, columns, pilasters, casework and cabinets in toe spaces, and other permanent fixtures in rooms and areas where base is required.
- D. Install resilient base in lengths as long as practical without gaps at seams and with tops of adjacent pieces aligned.
- E. Tightly adhere resilient base to substrate throughout length of each piece, with base in continuous contact with horizontal and vertical substrates.
- F. Do not stretch resilient base during installation.
- G. On masonry surfaces or other similar irregular substrates, fill voids along top edge of resilient base with manufacturer's recommended adhesive filler material.
- H. Job-Formed Corners:
  - 1. Outside Corners: Use straight pieces of maximum lengths possible and form with returns not less than 3 inches in length.
    - a. Form without producing discoloration (whitening) at bends.
  - 2. Inside Corners: Use straight pieces of maximum lengths possible and form with returns not less than 3 inches in length.
    - a. Miter or cope corners to minimize open joints.



3.6 RESILIENT ACCESSORY INSTALLATION

- B. Comply with manufacturer's written instructions for installing resilient accessories.
- C. Resilient Molding Accessories: Butt to adjacent materials and tightly adhere to substrates throughout length of each piece. Install reducer strips at edges of floor covering that would otherwise be exposed.
- D. See sheet I-601 for transition detail of LVT to CPT-1 and recommended transition.

3.7 CLEANING AND PROTECTION

- B. Comply with manufacturer's written instructions for cleaning and protecting resilient products.
- C. Perform the following operations immediately after completing resilient-product installation:
  - 1. Remove adhesive and other blemishes from exposed surfaces.
- D. Protect resilient products from mars, marks, indentations, and other damage from construction operations and placement of equipment and fixtures during remainder of construction period.
- E. Cover resilient products subject to wear and foot traffic until Substantial Completion.

END OF SECTION 096513

## SECTION 096519 - RESILIENT TILE FLOORING

### PART 1 - GENERAL

#### 1.3 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.4 SUMMARY

- A. Section Includes:
  - 1. Solid vinyl floor tile (LVT).

#### 1.5 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: For each type of floor tile. Include floor tile layouts, edges, columns, doorways, enclosing partitions, built-in furniture, cabinets, and cutouts.
  - 1. Show details of special patterns.

#### 1.6 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For each type of floor tile to include in maintenance manuals.

#### 1.7 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Floor Tile: Furnish one box for every 50 boxes or fraction thereof, of each type, color, and pattern of floor tile installed.

#### 1.8 QUALITY ASSURANCE

- A. Installer Qualifications: A qualified installer who employs workers for this Project who are competent in techniques required by manufacturer for floor tile installation and seaming method indicated.

1. Engage an installer who employs workers for this Project who are trained or certified by floor tile manufacturer for installation techniques required.
2. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
3. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

#### 1.9 DELIVERY, STORAGE, AND HANDLING

- A. Store floor tile and installation materials in dry spaces protected from the weather, with ambient temperatures maintained within range recommended by manufacturer, but not less than 50 deg
- B. FIELD CONDITIONS
- C. Maintain ambient temperatures within range recommended by manufacturer, but not less than 70 deg F or more than 95 deg F, in spaces to receive floor tile during the following time periods:
  1. 48 hours before installation.
  2. During installation.
  3. 48 hours after installation.
- D. After installation and until Substantial Completion, maintain ambient temperatures within range recommended by manufacturer, but not less than 55 deg F or more than 95 deg F.
- E. Close spaces to traffic during floor tile installation.
- F. Close spaces to traffic for 48 hours after floor tile installation.
- G. Install floor tile after other finishing operations, including painting, have been completed.

### PART 2 - PRODUCTS

#### 2.3 PERFORMANCE REQUIREMENTS

- A. Fire-Test-Response Characteristics: For resilient tile flooring, as determined by testing identical products according to ASTM E 648 or NFPA 253 by a qualified testing agency.
  1. Critical Radiant Flux Classification: Class I, not less than 0.45 W/sq. cm.

#### 2.4 SOLID VINYL FLOOR TILE LVT-1

- A. **Products:** Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
  1. Basis of Design: Mohawk Group.

2. Mannington Commercial Flooring
  3. Tandus
  4. Or approved equal.
- B. Tile Standard: ASTM F 1700.
3. Class: Class III, printed film vinyl tile.
  4. Type: A, embossed surface.
- C. Thickness: 0.2" inch (5mm).
- D. Wear Layer: 20 mil (0.5mm).
- E. Size: 18"x36".
- F. Colors and Patterns: see finish legend on architectural drawings I-601.

### PART 3 - EXECUTION

#### 3.3 EXAMINATION

- A. Examine substrates, with Installer present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the Work.
1. Verify that finishes of substrates comply with tolerances and other requirements specified in other Sections and that substrates are free of cracks, ridges, depressions, scale, and foreign deposits that might interfere with adhesion of floor tile.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.4 PREPARATION

- A. Prepare substrates according to floor tile manufacturer's written instructions to ensure adhesion of resilient products.
- B. Concrete Substrates: Prepare according to ASTM F 710.
1. Verify that substrates are dry and free of curing compounds, sealers, and hardeners.
  2. Remove substrate coatings and other substances that are incompatible with adhesives and that contain soap, wax, oil, or silicone, using mechanical methods recommended by floor tile manufacturer. Do not use solvents.
  3. Alkalinity and Adhesion Testing: Perform tests recommended by floor tile manufacturer. Proceed with installation only after substrate alkalinity falls within range on pH scale recommended by manufacturer in writing, but not less than 5 or more than 10. Insert number pH.

4. Moisture Testing: Proceed with installation only after substrates pass testing according to floor tile manufacturer's written recommendations, but not less stringent than the following:
  - a. Perform anhydrous calcium chloride test according to ASTM F 1869. Proceed with installation only after substrates have maximum moisture-vapor-emission rate of 8 lb of water/1000 sq. ft. in 24 hours.
  - b. Perform relative humidity test using in situ probes according to ASTM F 2170. Proceed with installation only after substrates have a maximum 90 percent relative humidity level.
- C. Fill cracks, holes, and depressions in substrates with trowelable leveling and patching compound; remove bumps and ridges to produce a uniform and smooth substrate.
- D. Do not install floor tiles until they are the same temperature as the space where they are to be installed.
  1. At least 48 hours in advance of installation, move resilient floor tile and installation materials into spaces where they will be installed.
- E. Immediately before installation, sweep and vacuum clean substrates to be covered by resilient floor tile.

### 3.5 FLOOR TILE INSTALLATION

- A. Comply with manufacturer's written instructions for installing floor tile.
- B. Lay out floor tiles from center marks established with principal walls, discounting minor offsets, so tiles at opposite edges of room are of equal width. Adjust as necessary to avoid using cut widths that equal less than one-half tile at perimeter.
  1. Lay tiles square with room axis.
- C. Match floor tiles for color and pattern by selecting tiles from cartons in the same sequence as manufactured and packaged, if so numbered. Discard broken, cracked, chipped, or deformed tiles.
  1. Lay tiles with grain running in one direction.
- D. Scribe, cut, and fit floor tiles to butt neatly and tightly to vertical surfaces and permanent fixtures including built-in furniture, cabinets, pipes, outlets, and door frames.
- E. Extend floor tiles into toe spaces, door reveals, closets, and similar openings. Extend floor tiles to center of door openings.
- F. Maintain reference markers, holes, and openings that are in place or marked for future cutting by repeating on floor tiles as marked on substrates. Use chalk or other nonpermanent marking device.

- G. Install floor tiles on covers for telephone and electrical ducts, building expansion-joint covers, and similar items in finished floor areas. Maintain overall continuity of color and pattern between pieces of tile installed on covers and adjoining tiles. Tightly adhere tile edges to substrates that abut covers and to cover perimeters.
- H. Adhere floor tiles to flooring substrates using a full spread of adhesive applied to substrate to produce a completed installation without open cracks, voids, raising and puckering at joints, telegraphing of adhesive spreader marks, and other surface imperfections.

### 3.6 CLEANING AND PROTECTION

- A. Comply with manufacturer's written instructions for cleaning and protecting floor tile.
- B. Perform the following operations immediately after completing floor tile installation:
  - 1. Remove adhesive and other blemishes from exposed surfaces.
  - 2. Sweep and vacuum surfaces thoroughly.
  - 3. Spray neutral pH cleaner, onto the floor in manageable area (spray mist will dry quickly). Use a micro fiber wet mop pad to mop the floor with cleaner. If pad becomes dirty, be sure to replace the pad with a new micro fiber wet mop pad. Work floor in sections.
- C. Protect floor tile from mars, marks, indentations, and other damage from construction operations and placement of equipment and fixtures during remainder of construction period.
- D. Cover floor tile until Substantial Completion.

END OF SECTION 096519

## SECTION 099123 - INTERIOR PAINTING

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes surface preparation and the application of paint systems on interior substrates.
  - 1. Hollow Metal Frames.
  - 2. Gypsum board.
- B. Section included specification for field applied dry erase coating & magnetic wallcovering.
- C. Related Requirements:
  - 1. Section 055000 "Metal Fabrications" for shop priming metal fabrications.

#### 1.3 DEFINITIONS

- A. MPI Gloss Level 1: Not more than five units at 60 degrees and 10 units at 85 degrees, according to ASTM D 523.
- B. MPI Gloss Level 2: Not more than 10 units at 60 degrees and 10 to 35 units at 85 degrees, according to ASTM D 523.
- C. MPI Gloss Level 3: 10 to 25 units at 60 degrees and 10 to 35 units at 85 degrees, according to ASTM D 523.
- D. MPI Gloss Level 4: 20 to 35 units at 60 degrees and not less than 35 units at 85 degrees, according to ASTM D 523.
- E. MPI Gloss Level 5: 35 to 70 units at 60 degrees, according to ASTM D 523.
- F. MPI Gloss Level 6: 70 to 85 units at 60 degrees, according to ASTM D 523.
- G. MPI Gloss Level 7: More than 85 units at 60 degrees, according to ASTM D 523.

#### 1.4 PRE-APPLICATION MEETING

- A. Prior to installation of dry erase paint and magnetic wallcovering, installer and general contractor to meet on site with manufacturer's representative to review site conditions.

#### 1.5 ACTION SUBMITTALS

- A. Product Data: For each type of product. Include preparation requirements and application instructions.
  - 1. Include Printout of current "MPI Approved Products List" for each product category specified, with the proposed product highlighted.
  - 2. Indicate VOC content.
- B. Samples for Verification: For each type of paint system and in each color and gloss of topcoat.
  - 1. Submit Samples on rigid backing, 8 inches square.
  - 2. Step coats on Samples to show each coat required for system.
  - 3. Label each coat of each Sample.
  - 4. Label each Sample for location and application area.

#### 1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials, from the same product run, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Paint: 10 percent, but not less than 1 gal. of each material and color applied.

#### 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store materials not in use in tightly covered containers in well-ventilated areas with ambient temperatures continuously maintained at not less than 45 deg F .
  - 1. Maintain containers in clean condition, free of foreign materials and residue.
  - 2. Remove rags and waste from storage areas daily.

#### 1.8 FIELD CONDITIONS

- A. Apply paints only when temperature of surfaces to be painted and ambient air temperatures are between 50 and 95 deg F.
- B. Do not apply paints when relative humidity exceeds 85 percent; at temperatures less than 5 deg F above the dew point; or to damp or wet surfaces.



## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Subject to compliance with requirements, provide products indicated in Interior Painting Schedule or comparable product by one of the following:
  - 1. Basis of Design: Sherwin Williams.
  - 2. PPG
  - 3. Benjamin Moore
  - 4. Or approved equal.
  
- B. Products: Subject to compliance with requirements, provide one of the products available products that may be incorporated into the Work include, but are not limited to products listed in the Interior Painting Schedule for the paint category indicated.

### 2.2 PAINT, GENERAL

- A. MPI Standards: Products shall comply with MPI standards indicated and shall be listed in its "MPI Approved Products Lists."
  
- B. Material Compatibility:
  - 1. Materials for use within each paint system shall be compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer, based on testing and field experience.
  - 2. For each coat in a paint system, products shall be recommended in writing by topcoat manufacturers for use in paint system and on substrate indicated.
  
- C. VOC Content: Products shall comply with VOC limits of authorities having jurisdiction and, for interior paints and coatings applied at Project site, the following VOC limits, exclusive of colorants added to a tint base:
  - 1. Flat Paints and Coatings: 50 g/L.
  - 2. Nonflat Paints and Coatings: 150 g/L.
  - 3. Dry-Fog Coatings: 400 g/L.
  - 4. Primers, Sealers, and Undercoaters: 200 g/L.
  - 5. Zinc-Rich Industrial Maintenance Primers: 340 g/L.
  - 6. Floor Coatings: 100 g/L.
  - 7. Shellacs, Clear: 730 g/L.
  - 8. Shellacs, Pigmented: 550 g/L.
  
- D. Colors: As indicated in a color schedule.
  - 1. Five percent of surface area will be painted with deep tones.

## 2.3 SOURCE QUALITY CONTROL

- A. Testing of Paint Materials: Owner reserves the right to invoke the following procedure:
1. Owner will engage the services of a qualified testing agency to sample paint materials. Contractor will be notified in advance and may be present when samples are taken. If paint materials have already been delivered to Project site, samples may be taken at Project site. Samples will be identified, sealed, and certified by testing agency.
  2. Testing agency will perform tests for compliance with product requirements.
  3. Owner may direct Contractor to stop applying paints if test results show materials being used do not comply with product requirements. Contractor shall remove noncomplying paint materials from Project site, pay for testing, and repaint surfaces painted with rejected materials. Contractor will be required to remove rejected materials from previously painted surfaces if, on repainting with complying materials, the two paints are incompatible.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates and conditions, with Applicator present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the Work.
- B. Maximum Moisture Content of Substrates: When measured with an electronic moisture meter as follows:
1. Gypsum Board: 12 percent.
  2. Masonry (Clay and CMU): 12 percent.
- C. Gypsum Board Substrates: Verify that finishing compound is sanded smooth.
- D. Verify suitability of substrates, including surface conditions and compatibility, with existing finishes and primers.
- E. Proceed with coating application only after unsatisfactory conditions have been corrected.
1. Application of coating indicates acceptance of surfaces and conditions.

### 3.2 PREPARATION

- A. Comply with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual" applicable to substrates and paint systems indicated.
- B. Remove hardware, covers, plates, and similar items already in place that are removable and are not to be painted. If removal is impractical or impossible because of size or weight of item, provide surface-applied protection before surface preparation and painting.

1. After completing painting operations, use workers skilled in the trades involved to reinstall items that were removed. Remove surface-applied protection if any.
- C. Clean substrates of substances that could impair bond of paints, including dust, dirt, oil, grease, and incompatible paints and encapsulants.
1. Remove incompatible primers and reprime substrate with compatible primers or apply tie coat as required to produce paint systems indicated.

### 3.3 APPLICATION

- A. Apply paints according to manufacturer's written instructions and to recommendations in "MPI Manual."
1. Use applicators and techniques suited for paint and substrate indicated.
  2. Paint surfaces behind movable equipment and furniture same as similar exposed surfaces. Before final installation, paint surfaces behind permanently fixed equipment or furniture with prime coat only.
  3. Paint front and backsides of access panels, removable or hinged covers, and similar hinged items to match exposed surfaces.
  4. Do not paint over labels of independent testing agencies or equipment name, identification, performance rating, or nomenclature plates.
  5. Primers specified in painting schedules may be omitted on items that are factory primed or factory finished if acceptable to topcoat manufacturers.
- B. Tint each undercoat a lighter shade to facilitate identification of each coat if multiple coats of same material are to be applied. Tint undercoats to match color of topcoat, but provide sufficient difference in shade of undercoats to distinguish each separate coat.
- C. If undercoats or other conditions show through topcoat, apply additional coats until cured film has a uniform paint finish, color, and appearance.
- D. Apply paints to produce surface films without cloudiness, spotting, holidays, laps, brush marks, roller tracking, runs, sags, ropiness, or other surface imperfections. Cut in sharp lines and color breaks.
- E. Painting Fire Suppression, Plumbing, HVAC, Electrical, Communication, and Electronic Safety and Security Work:
1. Paint portions of internal surfaces of metal ducts, without liner, behind air inlets and outlets that are visible from occupied spaces.

### 3.4 FIELD QUALITY CONTROL

- A. Dry Film Thickness Testing: Owner may engage the services of a qualified testing and inspecting agency to inspect and test paint for dry film thickness.

1. Contractor shall touch up and restore painted surfaces damaged by testing.
2. If test results show that dry film thickness of applied paint does not comply with paint manufacturer's written recommendations, Contractor shall pay for testing and apply additional coats as needed to provide dry film thickness that complies with paint manufacturer's written recommendations.

### 3.5 CLEANING AND PROTECTION

- A. At end of each workday, remove rubbish, empty cans, rags, and other discarded materials from Project site.
- B. After completing paint application, clean spattered surfaces. Remove spattered paints by washing, scraping, or other methods. Do not scratch or damage adjacent finished surfaces.
- C. Protect work of other trades against damage from paint application. Correct damage to work of other trades by cleaning, repairing, replacing, and refinishing, as approved by Architect, and leave in an undamaged condition.
- D. At completion of construction activities of other trades, touch up and restore damaged or defaced painted surfaces.

### 3.6 INTERIOR PAINTING SCHEDULE

#### A. Hollow Metal Frames & Existing Paint Wood Doors:

1. Industrial Water Based Epoxy:
  - a. Prime Coat: Primer, galvanized, existing painted wood doors.
    - 1) Primer, galvanized, multi-purpose latex: Pro Industrial Pro-Cryl Universal Primer, B66W310
  - b. Intermediate Coat: Pre-Catalyzed Epoxy, interior, water based, matching topcoat.
  - c. Topcoat: Pre-Catalyzed Epoxy, interior, water based, semi-gloss
    - 1) Pre-Catalyzed Epoxy, interior, water based, semi-gloss, S-W Pro Industrial Pre-Catalyzed Water Based Epoxy, K46-151 Series, at 4.0 mils wet, 1.5 mils dry per coat

#### B. Gypsum Board Substrates:

1. Industrial Water Based Epoxy:
  - a. Industrial Water Based Epoxy to be located in the following areas: Labs, Corridors, Consult rooms, Treatment rooms, Common areas, Living room, Work rooms, Student area, and Great room.
  - b. Industrial Water Based Epoxy:

- 1) Prime Coat: Primer, galvanized, multi-purpose latex.
    - a) Primer, galvanized, multi-purpose latex: Multi-purpose Interior/Exterior Latex Primer/Sealer B51-450
  - c. Intermediate Coat: Pre-Catalyzed Epoxy, interior, water based, matching topcoat.
  - d. Topcoat: Pre-Catalyzed Epoxy, interior, water based, eg-shell.
    - 1) Pre-Catalyzed Epoxy, interior, water based, eg-shell, S-W Pro Industrial Pre-Catalyzed Water Based Epoxy, K45-151 Series, at 4.0 mils wet, 1.5 mils dry per coat.
2. Interior Acrylic Enamel:
- a. Interior acrylic enamel to be located in the following areas: offices, and conference rooms. All other areas to receive Industrial water-based epoxy.
  - b. Prime Coat: Primer, galvanized, multi-purpose latex.
    - 1) Primer, galvanized, Sherwin Williams multi-purpose latex: Multi-purpose Interior/Exterior Latex Primer/Sealer B51-450
  - c. Intermediate Coat: Interior Acrylic Enamel matching top coat.
  - d. Topcoat: Interior Acrylic Enamel, pearl.
    - 1) Interior Acrylic Enamel, Sherwin Williams Cashmere Interior Acrylic Pearl D15-150 Series.

END OF SECTION 099123

## SECTION 102800 – TOILET AND BATH ACCESSORIES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes
  - 1. Public-use washroom accessories.

#### 1.3 SUBMITTALS

- A. Product Data: For each type of product indicated. Include the following:
  - 1. Construction details and dimensions.
  - 2. Anchoring and mounting requirements, including requirements for cutouts in other work and substrate preparation.
  - 3. Material and finish descriptions.
  - 4. Features that will be included for Project.
  - 5. Manufacturer's warranty.
- B. Product Schedule: Indicating types, quantities, sizes, and installation locations by room of each accessory required.
  - 1. Identify locations using room designations indicated.
  - 2. Identify products using designations indicated.
- C. Warranty: Sample of special warranty.

#### 1.4 QUALITY ASSURANCE

- A. Source Limitations: For products listed together in the same Part 2 articles, obtain products from single source from single manufacturer.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.

#### 1.5 COORDINATION

- A. Coordinate accessory locations with other work to prevent interference with clearances required for access by people with disabilities, and for proper installation, adjustment, operation, cleaning, and servicing of accessories.
- B. Deliver inserts and anchoring devices set into concrete or masonry as required to prevent delaying the Work.

## 1.6 WARRANTY

- A. Special Mirror Warranty: Manufacturer's standard form in which manufacturer agrees to replace mirrors that develop visible silver spoilage defects and that fail in materials or workmanship within specified warranty period.
  - 1. Warranty Period: 15 years from date of Substantial Completion.

## PART 2 - PRODUCTS

### 2.1 MATERIALS

- A. Stainless Steel: ASTM A 666, Type 304, 0.031-inch minimum nominal thickness unless otherwise indicated.
- B. Brass: ASTM B 19, flat products; ASTM B 16/B 16M, rods, shapes, forgings, and flat products with finished edges; or ASTM B 30, castings.
- C. Steel Sheet: ASTM A 1008/A 1008M, Designation CS (cold rolled, commercial steel), 0.036-inch minimum nominal thickness.
- D. Galvanized-Steel Sheet: ASTM A 653/A 653M, with G60 hot-dip zinc coating.
- E. Galvanized-Steel Mounting Devices: ASTM A 153/A 153M, hot-dip galvanized after fabrication.
- F. Fasteners: Screws, bolts, and other devices of same material as accessory unit and tamper-and-theft resistant where exposed, and of galvanized steel where concealed.
- G. Chrome Plating: ASTM B 456, Service Condition Number SC 2 (moderate service).
- H. Mirrors: ASTM C 1503, Mirror Glazing Quality, clear-glass mirrors, nominal 6.0 mm thick.
- I. ABS Plastic: Acrylonitrile-butadiene-styrene resin formulation.

### 2.2 PUBLIC-USE WASHROOM ACCESSORIES

- A. Manufacturers: Subject to compliance with requirements, manufacturers offering products which may be incorporated into the work include, but are not limited to, the following :

1. American Specialties, Inc.
2. Bobrick Washroom Equipment, Inc.
3. Bradley Corporation.

B. Toilet Tissue (Roll) Dispenser **TTD**:

1. College provided contractor installed toilet paper dispenser.

C. Paper Towel Dispenser **PTD**:

1. College provided contractor installed toilet paper dispenser.

D. Grab Bar **GB-1, GB-2, GB-3**:

1. Basis-of-Design Product: Bradley Model 812-2.
2. Mounting: Flanges with concealed fasteners.
3. Material: Stainless steel, 18 gages thick.
  - a. Finish: Smooth, No. 4 finish (satin) on ends and slip-resistant texture in grip area.
4. Outside Diameter: 1-1/2 inches.
5. Configuration and Length: As indicated on Drawings.

E. Mirror Unit **MF**:

1. Basis-of-Design Product: Mirror, 2'-0" x 3'-0".
2. Mounting: Surface

F. Liquid-Soap Dispenser. **SD**:

1. College provided contractor installed toilet paper dispenser.

G. Robe Hook **RH**:

1. Basis-of-Design Product: Bradley Model 915.
2. Description: Clothes hook.
3. Materials: 12 Gauge Stainless Steel with exposed in satin finish.

H. Sanitary-Napkin Disposal Unit **SND**:

1. Basis-of-Design Product: Bradley Model 4A10
2. Mounting: Partition mounted,.
3. Door or Cover: push flap door.
4. Receptacle: 22 gauge stainless steel with tumbler locks keyed with other Bradley units.
5. Material and Finish: 22 gage stainless steel.

## 2.3 FABRICATION



- A. General: Fabricate units with tight seams and joints, and exposed edges rolled. Hang doors and access panels with full-length, continuous hinges. Equip units for concealed anchorage and with corrosion-resistant backing plates.
- B. Keys: Provide universal keys for internal access to accessories for servicing and resupplying. Provide minimum of six keys to Owner's representative.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- A. Install accessories according to manufacturers' written instructions, using fasteners appropriate to substrate indicated and recommended by unit manufacturer. Install units level, plumb, and firmly anchored in locations and at heights indicated.
- B. Grab Bars: Install to withstand a downward load of at least 250 lbf , when tested according to ASTM F 446.

#### 3.2 ADJUSTING AND CLEANING

- A. Adjust accessories for unencumbered, smooth operation. Replace damaged or defective items.
- B. Remove temporary labels and protective coatings.
- C. Clean and polish exposed surfaces according to manufacturer's written recommendations.

END OF SECTION 102800