

**SECTION 009111  
ADDENDUM NUMBER 1**

**PARTICULARS**

- 1.01 DATE: MARCH 17, 2022**
- 1.02 PROJECT: MIDLANDS TECHNICAL COLLEGE AUTO TRAINING FACILITY AHU REPLACEMENT**
- 1.03 PROJECT NUMBER: H59-N127-FW**
- TO: PROSPECTIVE BIDDERS:**
- 2.01 THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE ORIGINAL PROCUREMENT DOCUMENTS DATED AUGUST 7, 2020, WITH AMENDMENTS AND ADDITIONS NOTED BELOW.**
- 2.02 ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID FORM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.**
- 2.03 THIS ADDENDUM CONSISTS OF 1 PAGE AND THE FOLLOWING ATTACHMENTS, SPECIFICATIONS, AND DRAWINGS:**
- A. Pre-Bid Sign-in Sheet
  - B. E3.1 - ELECTRICAL MECHANICAL EQUIPMENT PLAN - FIRST FLOOR RENOVATION
- 2.04 LAST DAY FOR QUESTIONS SHALL BE SUBMITTED TO GMK BY NOON ON 3/21/22**
- 2.05 LAST ADDENDUM WILL BE ISSUED ON 3/21/22.**
- 2.06 BIDS SHALL BE RECEIVED BY 2:00 PM ON 3/29/22 AT LOCATION NOTED IN SE-310.**
- 2.07 ANY AND ALL HAZARDOUS MATERIALS WILL BE REMOVED BY THE OWNER.**
- 2.08 CONTROL MANAGEMENT (CMI) IS THE CONTROLS VENDOR ON THIS PROJECT.**
- 2.09 DRAWINGS CALL FOR THE CONTRACTOR TO RECLAIM EXISTING REFRIGERANT AND PROPERLY DISPOSE IN ACCORDANCE WITH DHEC AND THE EPA. MIDLANDS TECH DOES NOT WANT RECLAIMED REFRIGERANT.**
- 2.10 MIDLANDS TECH WILL NEGOTIATE WITH THE LOWEST BIDDER THE TIME FRAME FOR INSTALLATION BASED ON THE DELIVERY SCHEUDLE OF THE EQUIPMENT.**
- CHANGES TO DRAWINGS:**
- 3.01 DRAWING E3.1 - ELECTRICAL MECHANICAL EQUIPMENT PLAN - FIRST FLOOR RENOVATION**
- A. Delete Renovation Keyed Notes in its entirety.

**END OF SECTION**





**1** FIRST FLOOR - RENOVATION  
SCALE: 1/8" = 1'-0"

MECHANICAL EQUIPMENT SCHEDULE								
EQUIPMENT TAG	VOLTAGE	AMPERE RATING	NUMBER OF POLES	DISCONNECT TYPE	NEMA ENCLOSURE	PANEL	CIRCUIT #	COMMENTS
AHU-1	480 V	15 A	3	S6	NEMA 1	HM	13, 15, 17	

**RENOVATION KEYED NOTES:** ○

**GMK ASSOCIATES**  
DESIGN-BUILD DIVISION, INC.  
Design/Planning/Construction  
1201 Main Street, Suite 2100  
Columbia, S.C. 29201  
tel. 803-256-0000  
fax 803-255-7243

ALL RIGHTS RESERVED. THIS DRAWING AND THE DESIGN SHOWN THEREON ARE COPYRIGHTED AND PRESCRIBED BY THE LAWS OF THE UNITED STATES AND ARE THE PROPERTY OF GMK ASSOCIATES ARCHITECTURAL DIVISION. ANYONE DUPLICATING, REPRODUCING OR CAUSING TO BE REPRODUCED THE WHOLE OR PART OF THESE DRAWINGS OR THE DESIGN THEREON WITHOUT PERMISSION OF THE ARCHITECT WILL BE SUBJECT TO LEGAL ACTION.

CONTRACTORS SHALL BE AWARE THAT THESE DRAWINGS ARE THE SOLE PROPERTY OF GMK ASSOCIATES ARCHITECTURAL DIVISION. CONTRACTORS SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AGENCIES. CONTRACTORS SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AGENCIES. CONTRACTORS SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AGENCIES. CONTRACTORS SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AGENCIES.

consultants

owner

MIDLANDS TECHNICAL COLLEGE  
BELTLINE CAMPUS  
316 S. BELTLINE BLVD.  
COLUMBIA, SC 29205  
project name  
AUTO TRAINING FACILITY  
AHU REPLACEMENT  
H59-N127-FW  
project number  
21060.01

seals/signature



issued for  
**CONSTRUCTION**

date  
**MARCH 4, 2022**

number	item	date

key plan



**N** Key Plan

sheet title  
**ELECTRICAL MECHANICAL  
EQUIPMENT PLAN - FIRST  
FLOOR RENOVATION**

sheet number

**E3.1**

drawn by RMI  
checked by RMI