

**SECTION 009112
ADDENDUM NUMBER 2**

PARTICULARS

1.01 DATE: MARCH 22, 2022

**1.02 PROJECT: MIDLANDS TECHNICAL COLLEGE AUTO TRAINING FACILITY AHU
REPLACEMENT**

1.03 PROJECT NUMBER: H59-N127-FW

TO: PROSPECTIVE BIDDERS:

2.01 THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE ORIGINAL PROCUREMENT DOCUMENTS DATED MARCH 4, 2022, WITH AMENDMENTS AND ADDITIONS NOTED BELOW.

2.02 ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID FORM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.

2.03 THIS ADDENDUM CONSISTS OF 1 PAGE AND THE FOLLOWING ATTACHMENTS, SPECIFICATIONS, AND DRAWINGS:

A. M2.1 - FIRST FLOOR PLAN - HVAC RENOVATION

2.04 FIRE ALARM MANUFACTURER NOTIFIER BY HONEYWELL.

2.05 ALL REFRIGERANT SPECIALITIES SHALL BE PROVIDED BY THE EQUIPMENT MANUFACTURER. EQUIPMENT MANUFACTURER SHALL DETERMINE WHAT REFRIGERANT SPECIALITIES (I.E. TRAP, DRYERS, SITE GLASSES, ETC.) ARE REQUIRED FOR THEIR SYSTEM.

CHANGES TO DRAWINGS:

3.01 DRAWING M2.1 - FIRST FLOOR PLAN - HVAC RENOVATION

A. Add Duct Detector and interlock with Honeywell fire alarm system.

END OF SECTION

