

Addendum Number Two

Date of Issue: October 10, 2025

Project: MTC – CE BUILDING RENOVATION HARBISON CAMPUS

Project Number: H59-6330-PD

This addendum modifies the Contract documents only in the manner and to the extent stated herein and shown on any accompanying drawings and will become part of the Contract Documents. Except as specified or otherwise indicated by this Addendum, all work shall be in accordance with the basic requirements of the Contract Documents.

BIDDERS SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY CONSTITUTE A REASON TO REJECT THE BID.

Prior Approvals

Submittals are reviewed for conformance with design intent and general compliance with the Contract Documents only. Notations do not authorize changes to contract sum. Approval, comments and/or corrections do not relieve the Contractor from compliance with the Contract Documents. The Contractor is responsible for confirming and coordinating all quantities, dimensions, tolerances, clearances, fabrication processes, techniques and sequences of construction, compatibility of materials and methods, coordination of their work with other trades, performance of work in a safe and satisfactory manner and for full compliance with the Contract Documents.

The following products and/or vendors have been approved to bid with the noted exceptions.

1. The CLS Lighting Fixture Package dated September 22, 2025
2. The SESCO Lighting Fixture Package dated September 30, 2025.

Clarifications:

1. Sheet S1.0, S1.1- Contractor is responsible for means and methods to execute the scope of work in the Construction Documents, including but not limited to, potential modifications to ductwork and other systems as required to install structural components.

Changes to the Project Manual:

Item No.	Description
----------	-------------

None	
------	--

Changes to the Drawings:

Item No.	Description
1.	Sheet A8.1- Interior Finish Legend-TG-1- Texas Granite Vinyl Tile. Locations. Delete "Multipurpose" from locations.
2.	Sheet A8.1- Interior Finish Legend-TP-1- Toilet Partitions. Add "Height:55 inches, Standard Hardware, Floor mounted overhead braced configuration, Color selected from standard color collection".
3.	Sheet A7.0- Door Schedule. Door # 113, 113A, 113B, and 114. Change Door Material from "Alum/ Glass To "HM/ Glass". Change door finish from "Factory" to "Paint".

End of Addendum Two