



HVAC DEMOLITION LEGEND

- EXISTING EQUIPMENT, DUCTWORK AND DIFFUSERS TO REMAIN
- EXISTING EQUIPMENT, DUCTWORK AND DIFFUSERS TO BE REMOVED

HVAC DEMOLITION NOTES

1. COORDINATE WITH THE OWNER THE PHASING OF ALL DEMOLITION AND NEW WORK, ALONG WITH ANY SHUT DOWNS REQUIRED FOR SYSTEM CHANGE OVER.
2. THE CONTRACTOR IS RESPONSIBLE FOR THE DISPOSAL OF ALL HVAC EQUIPMENT, ETC. TO BE REMOVED AFTER FIRST ALLOWING THE OWNER THE OPPORTUNITY TO KEEP ANY ITEMS THEY CHOOSE.
3. REMOVE EXISTING HVAC EQUIPMENT, DUCTWORK, PIPING, GRILLES, CONTROLS, ETC. AS INDICATED ON THE PLANS.
4. PATCH ALL HOLES IN EXISTING DUCTWORK THAT IS TO REMAIN.
5. PATCH ANY WALL OPENINGS CREATED BY DEMOLITION WORK. MATCH EXISTING MATERIALS AND FINISHES.
6. DEMOLITION PLANS ARE BASED ON "AS-BUILT" PRINTS; SOME FIELD DISCREPANCIES MAY EXIST. IF THERE IS ANY DOUBT CONCERNING THE REMOVAL OF AN ITEM SHOWN OR NOT SHOWN ON THESE PLANS, THE CONTRACTOR IS TO CONSULT THE ENGINEER PRIOR TO REMOVAL OF THE ITEM.

HVAC DEMOLITION FLOOR PLAN
SCALE: 1/4" = 1'-0"

REVISIONS	
DATE	DESCRIPTION

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND REMAINS THE PROPERTY OF FELKEL & HASTINGS. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED IN WRITTEN PERMISSION. © COPYRIGHT 2015 FELKEL & HASTINGS, CONSULTING MECHANICAL ENGINEERS

**ACADEMIC CENTER
AIR HANDLER
REPLACEMENT**

FELKEL & HASTINGS
Mechanical Engineers
2725 Cypress Street
Columbia, S.C. 29205

**MIDLANDS TECHNICAL
COLLEGE
AIRPORT CAMPUS
COLUMBIA, SC**

FOR REVIEW

FELKEL & HASTINGS
CONSULTING MECHANICAL ENGINEERS
No. 12548

LOUIS C. BUSTO
No. 000429

DRAWN BY:	JCR
CHECKED BY:	JHK
COMM NO.:	14-63
DATE:	8 SEPTEMBER 2015
DRAWING NAME:	
SCALE:	AS NOTED
MD-1	DRAWING NUMBER